

DRIVEWAYS – PARKING PAD - SIDEWALKS – PATIOS

Submit a completed Building Application along with 2 sets of plans and a plat of survey showing the location of driveway, parking pad, patio or sidewalks to the Building Department.

- When submitting permit locate improvement on your plat of survey include dimensions.
- Concrete driveways must be a minimum of 4" of crushed stone and 5" of concrete.
- Brick pavers must be a minimum of 4" – 6" of crushed stone base, 1" coarse sand, 2 3/8" minimum paver.
- Asphalt must be a minimum of 6" of crushed stone and 2 1/2" – 3" of surface asphalt.
- No driveway shall exceed 24 feet in width except that the width of a driveway may exceed 24 feet at the point that the driveway connects to a garage and from the connection to the garage for a distance not to exceed 30' toward the front lot line.
- No driveway shall have more than one curb cut.
- Circular driveways are prohibited.
- No lot shall have more than one driveway.
- Lots between 5,000 – 6000 sf, no more than 65% may be covered by impervious surfaces.
Lots between 6,001-8,000 sf, no more than 55%
Lots 8,001 sf & over, no more than 50%
- Abutting paved or gravel sidewalks or patios considered as part of driveway for purposes of determining overall width, size and area of driveway.
- A paved parking pad not to exceed 12' x 24' may be constructed adjacent to a garage on a lot provided that it complies with all other requirements of this section.
- No driveway located in a front yard of any lot shall extend more than 12' across the front elevation of the residence located on such lot except when the driveway connects to an attached garage.
- **Pre pour inspection required. Call 24 hours in advance to schedule. 708-343-8700.**

ENTRADAS – ACERAS DE LA PLATAFORMA DE ESTACIONAMIENTO – PATIOS

Envíe una aplicación de construcción completada junto con 2 conjuntos de planes y un plato de estudio que muestra la ubicación de la entrada, el cojín de estacionamiento, el patio o las aceras al Departamento de Construcción.

- Al enviar el permiso localizar la mejora en su plat de encuesta incluyen dimensiones.
- Las entradas de hormigón deben ser un mínimo de 4" de piedra triturada y 5" de hormigón.
- Las pavimentadoras de ladrillo deben ser un mínimo de 4" – 6" de base de piedra triturada, 1" de arena gruesa, 2 3/8" de pavimentación mínima.
- El asfalto debe ser un mínimo de 6" de piedra triturada y 2 1/2" – 3" de asfalto superficial.
- Ninguna entrada excederá los 24 pies de ancho, excepto que la anchura de una entrada puede exceder de 24 pies en el punto en que la entrada se conecta a un garaje y desde la conexión al garaje para una distancia que no exceda de 30' hacia la línea de lote principal.
- Ninguna entrada tendrá más de un corte de bordillo.
- Las entradas circulares están prohibidas.
- Ningún lote tendrá más de una entrada.
- Lotes entre 5.000 y 6000 sf, no más del 65% pueden estar cubiertos por superficies impermeables.
Lotes entre 6.001-8.000 sf, no más del 55%
Lotes 8.001 sf & over, no más del 50%
- Abutting paved o gravel sidewalks or patios considerados como parte de la entrada para determinar la anchura total, el tamaño y el área de entrada.
- Se puede construir una plataforma de aparcamiento pavimentada que no exceda de 12' x 24' adyacente a un garaje en un lote siempre que cumpla con todos los demás requisitos de esta sección.
- Ninguna entrada ubicada en un patio delantero de cualquier lote se extenderá más de 12' a través de la elevación frontal de la residencia ubicada en dicho lote, excepto cuando la entrada se conecta a un garaje adjunto.
- Al enviar el permiso localizar la mejora en su plat de encuesta incluyen dimensiones.
- **Se requiere una inspección previa al vertido. Llame con 24 horas de anticipación para programar. 708-343-8700.**

DRIVEWAYS – PARKING PAD - SIDEWALKS – PATIOS

Submit a completed Building Application along with 2 sets of plans and a plat of survey showing the location of driveway, parking pad, patio or sidewalks to the Building Department.

- When submitting permit locate improvement on your plat of survey include dimensions.
- Concrete driveways must be a minimum of 4" of crushed stone and 5" of concrete.
- Brick pavers must be a minimum of 4" – 6" of crushed stone base, 1" coarse sand, 2 3/8" minimum paver.
- Asphalt must be a minimum of 6" of crushed stone and 2 1/2" – 3" of surface asphalt.
- No driveway shall exceed 24 feet in width except that the width of a driveway may exceed 24 feet at the point that the driveway connects to a garage and from the connection to the garage for a distance not to exceed 30' toward the front lot line.
- No driveway shall have more than one curb cut.
- Circular driveways are prohibited.
- No lot shall have more than one driveway.
- Lots between 5,000 – 6000 sf, no more than 65% may be covered by impervious surfaces.
Lots between 6,001-8,000 sf, no more than 55%
Lots 8,001 sf & over, no more than 50%
- Abutting paved or gravel sidewalks or patios considered as part of driveway for purposes of determining overall width, size and area of driveway.
- A paved parking pad not to exceed 12' x 24' may be constructed adjacent to a garage on a lot provided that it complies with all other requirements of this section.
- No driveway located in a front yard of any lot shall extend more than 12' across the front elevation of the residence located on such lot except when the driveway connects to an attached garage.
- **Pre pour inspection required. Call 24 hours in advance to schedule. 708-343-8700.**

ENTRADAS – ACERAS DE LA PLATAFORMA DE ESTACIONAMIENTO – PATIOS

Envíe una aplicación de construcción completada junto con 2 conjuntos de planes y un plato de estudio que muestra la ubicación de la entrada, el cojín de estacionamiento, el patio o las aceras al Departamento de Construcción.

- Al enviar el permiso localizar la mejora en su plat de encuesta incluyen dimensiones.
- Las entradas de hormigón deben ser un mínimo de 4" de piedra triturada y 5" de hormigón.
- Las pavimentadoras de ladrillo deben ser un mínimo de 4" – 6" de base de piedra triturada, 1" de arena gruesa, 2 3/8" de pavimentación mínima.
- El asfalto debe ser un mínimo de 6" de piedra triturada y 2 1/2" – 3" de asfalto superficial.
- Ninguna entrada excederá los 24 pies de ancho, excepto que la anchura de una entrada puede exceder de 24 pies en el punto en que la entrada se conecta a un garaje y desde la conexión al garaje para una distancia que no exceda de 30' hacia la línea de lote principal.
- Ninguna entrada tendrá más de un corte de bordillo.
- Las entradas circulares están prohibidas.
- Ningún lote tendrá más de una entrada.
- Lotes entre 5.000 y 6000 sf, no más del 65% pueden estar cubiertos por superficies impermeables.
Lotes entre 6.001-8.000 sf, no más del 55%
Lotes 8.001 sf & over, no más del 50%
- Abutting paved o gravel sidewalks or patios considerados como parte de la entrada para determinar la anchura total, el tamaño y el área de entrada.
- Se puede construir una plataforma de aparcamiento pavimentada que no exceda de 12' x 24' adyacente a un garaje en un lote siempre que cumpla con todos los demás requisitos de esta sección.
- Ninguna entrada ubicada en un patio delantero de cualquier lote se extenderá más de 12' a través de la elevación frontal de la residencia ubicada en dicho lote, excepto cuando la entrada se conecta a un garaje adjunto.
- Al enviar el permiso localizar la mejora en su plat de encuesta incluyen dimensiones.
- **Se requiere una inspección previa al vertido. Llame con 24 horas de anticipación para programar. 708-343-8700.**

DRIVEWAYS – PARKING PAD - SIDEWALKS – PATIOS

Submit a completed Building Application along with 2 sets of plans and a plat of survey showing the location of driveway, parking pad, patio or sidewalks to the Building Department.

- When submitting permit locate improvement on your plat of survey include dimensions.
- Concrete driveways must be a minimum of 4" of crushed stone and 5" of concrete.
- Brick pavers must be a minimum of 4" – 6" of crushed stone base, 1" coarse sand, 2 3/8" minimum paver.
- Asphalt must be a minimum of 6" of crushed stone and 2 1/2" – 3" of surface asphalt.
- No driveway shall exceed 24 feet in width except that the width of a driveway may exceed 24 feet at the point that the driveway connects to a garage and from the connection to the garage for a distance not to exceed 30' toward the front lot line.
- No driveway shall have more than one curb cut.
- Circular driveways are prohibited.
- No lot shall have more than one driveway.
- Lots between 5,000 – 6000 sf, no more than 65% may be covered by impervious surfaces.
Lots between 6,001-8,000 sf, no more than 55%
Lots 8,001 sf & over, no more than 50%
- Abutting paved or gravel sidewalks or patios considered as part of driveway for purposes of determining overall width, size and area of driveway.
- A paved parking pad not to exceed 12' x 24' may be constructed adjacent to a garage on a lot provided that it complies with all other requirements of this section.
- No driveway located in a front yard of any lot shall extend more than 12' across the front elevation of the residence located on such lot except when the driveway connects to an attached garage.
- **Pre pour inspection required. Call 24 hours in advance to schedule. 708-343-8700.**

ENTRADAS – ACERAS DE LA PLATAFORMA DE ESTACIONAMIENTO – PATIOS

Envíe una aplicación de construcción completada junto con 2 conjuntos de planes y un plato de estudio que muestra la ubicación de la entrada, el cojín de estacionamiento, el patio o las aceras al Departamento de Construcción.

- Al enviar el permiso localizar la mejora en su plat de encuesta incluyen dimensiones.
- Las entradas de hormigón deben ser un mínimo de 4" de piedra triturada y 5" de hormigón.
- Las pavimentadoras de ladrillo deben ser un mínimo de 4" – 6" de base de piedra triturada, 1" de arena gruesa, 2 3/8" de pavimentación mínima.
- El asfalto debe ser un mínimo de 6" de piedra triturada y 2 1/2" – 3" de asfalto superficial.
- Ninguna entrada excederá los 24 pies de ancho, excepto que la anchura de una entrada puede exceder de 24 pies en el punto en que la entrada se conecta a un garaje y desde la conexión al garaje para una distancia que no exceda de 30' hacia la línea de lote principal.
- Ninguna entrada tendrá más de un corte de bordillo.
- Las entradas circulares están prohibidas.
- Ningún lote tendrá más de una entrada.
- Lotes entre 5.000 y 6000 sf, no más del 65% pueden estar cubiertos por superficies impermeables.
Lotes entre 6.001-8.000 sf, no más del 55%
Lotes 8.001 sf & over, no más del 50%
- Abutting paved o gravel sidewalks or patios considerados como parte de la entrada para determinar la anchura total, el tamaño y el área de entrada.
- Se puede construir una plataforma de aparcamiento pavimentada que no exceda de 12' x 24' adyacente a un garaje en un lote siempre que cumpla con todos los demás requisitos de esta sección.
- Ninguna entrada ubicada en un patio delantero de cualquier lote se extenderá más de 12' a través de la elevación frontal de la residencia ubicada en dicho lote, excepto cuando la entrada se conecta a un garaje adjunto.
- Al enviar el permiso localizar la mejora en su plat de encuesta incluyen dimensiones.
- **Se requiere una inspección previa al vertido. Llame con 24 horas de anticipación para programar. 708-343-8700.**

DRIVEWAYS – PARKING PAD - SIDEWALKS – PATIOS

Submit a completed Building Application along with 2 sets of plans and a plat of survey showing the location of driveway, parking pad, patio or sidewalks to the Building Department.

- When submitting permit locate improvement on your plat of survey include dimensions.
- Concrete driveways must be a minimum of 4" of crushed stone and 5" of concrete.
- Brick pavers must be a minimum of 4" – 6" of crushed stone base, 1" coarse sand, 2 3/8" minimum paver.
- Asphalt must be a minimum of 6" of crushed stone and 2 1/2" – 3" of surface asphalt.
- No driveway shall exceed 24 feet in width except that the width of a driveway may exceed 24 feet at the point that the driveway connects to a garage and from the connection to the garage for a distance not to exceed 30' toward the front lot line.
- No driveway shall have more than one curb cut.
- Circular driveways are prohibited.
- No lot shall have more than one driveway.
- Lots between 5,000 – 6000 sf, no more than 65% may be covered by impervious surfaces.
Lots between 6,001-8,000 sf, no more than 55%
Lots 8,001 sf & over, no more than 50%
- Abutting paved or gravel sidewalks or patios considered as part of driveway for purposes of determining overall width, size and area of driveway.
- A paved parking pad not to exceed 12' x 24' may be constructed adjacent to a garage on a lot provided that it complies with all other requirements of this section.
- No driveway located in a front yard of any lot shall extend more than 12' across the front elevation of the residence located on such lot except when the driveway connects to an attached garage.
- **Pre pour inspection required. Call 24 hours in advance to schedule. 708-343-8700.**

ENTRADAS – ACERAS DE LA PLATAFORMA DE ESTACIONAMIENTO – PATIOS

Envíe una aplicación de construcción completada junto con 2 conjuntos de planes y un plato de estudio que muestra la ubicación de la entrada, el cojín de estacionamiento, el patio o las aceras al Departamento de Construcción.

- Al enviar el permiso localizar la mejora en su plat de encuesta incluyen dimensiones.
- Las entradas de hormigón deben ser un mínimo de 4" de piedra triturada y 5" de hormigón.
- Las pavimentadoras de ladrillo deben ser un mínimo de 4" – 6" de base de piedra triturada, 1" de arena gruesa, 2 3/8" de pavimentación mínima.
- El asfalto debe ser un mínimo de 6" de piedra triturada y 2 1/2" – 3" de asfalto superficial.
- Ninguna entrada excederá los 24 pies de ancho, excepto que la anchura de una entrada puede exceder de 24 pies en el punto en que la entrada se conecta a un garaje y desde la conexión al garaje para una distancia que no exceda de 30' hacia la línea de lote principal.
- Ninguna entrada tendrá más de un corte de bordillo.
- Las entradas circulares están prohibidas.
- Ningún lote tendrá más de una entrada.
- Lotes entre 5.000 y 6000 sf, no más del 65% pueden estar cubiertos por superficies impermeables.
Lotes entre 6.001-8.000 sf, no más del 55%
Lotes 8.001 sf & over, no más del 50%
- Abutting paved o gravel sidewalks or patios considerados como parte de la entrada para determinar la anchura total, el tamaño y el área de entrada.
- Se puede construir una plataforma de aparcamiento pavimentada que no exceda de 12' x 24' adyacente a un garaje en un lote siempre que cumpla con todos los demás requisitos de esta sección.
- Ninguna entrada ubicada en un patio delantero de cualquier lote se extenderá más de 12' a través de la elevación frontal de la residencia ubicada en dicho lote, excepto cuando la entrada se conecta a un garaje adjunto.
- Al enviar el permiso localizar la mejora en su plat de encuesta incluyen dimensiones.
- **Se requiere una inspección previa al vertido. Llame con 24 horas de anticipación para programar. 708-343-8700.**

DRIVEWAYS – PARKING PAD - SIDEWALKS – PATIOS

Submit a completed Building Application along with 2 sets of plans and a plat of survey showing the location of driveway, parking pad, patio or sidewalks to the Building Department.

- When submitting permit locate improvement on your plat of survey include dimensions.
- Concrete driveways must be a minimum of 4" of crushed stone and 5" of concrete.
- Brick pavers must be a minimum of 4" – 6" of crushed stone base, 1" coarse sand, 2 3/8" minimum paver.
- Asphalt must be a minimum of 6" of crushed stone and 2 1/2" – 3" of surface asphalt.
- No driveway shall exceed 24 feet in width except that the width of a driveway may exceed 24 feet at the point that the driveway connects to a garage and from the connection to the garage for a distance not to exceed 30' toward the front lot line.
- No driveway shall have more than one curb cut.
- Circular driveways are prohibited.
- No lot shall have more than one driveway.
- Lots between 5,000 – 6000 sf, no more than 65% may be covered by impervious surfaces.
Lots between 6,001-8,000 sf, no more than 55%
Lots 8,001 sf & over, no more than 50%
- Abutting paved or gravel sidewalks or patios considered as part of driveway for purposes of determining overall width, size and area of driveway.
- A paved parking pad not to exceed 12' x 24' may be constructed adjacent to a garage on a lot provided that it complies with all other requirements of this section.
- No driveway located in a front yard of any lot shall extend more than 12' across the front elevation of the residence located on such lot except when the driveway connects to an attached garage.
- **Pre pour inspection required. Call 24 hours in advance to schedule. 708-343-8700.**

ENTRADAS – ACERAS DE LA PLATAFORMA DE ESTACIONAMIENTO – PATIOS

Envíe una aplicación de construcción completada junto con 2 conjuntos de planes y un plato de estudio que muestra la ubicación de la entrada, el cojín de estacionamiento, el patio o las aceras al Departamento de Construcción.

- Al enviar el permiso localizar la mejora en su plat de encuesta incluyen dimensiones.
- Las entradas de hormigón deben ser un mínimo de 4" de piedra triturada y 5" de hormigón.
- Las pavimentadoras de ladrillo deben ser un mínimo de 4" – 6" de base de piedra triturada, 1" de arena gruesa, 2 3/8" de pavimentación mínima.
- El asfalto debe ser un mínimo de 6" de piedra triturada y 2 1/2" – 3" de asfalto superficial.
- Ninguna entrada excederá los 24 pies de ancho, excepto que la anchura de una entrada puede exceder de 24 pies en el punto en que la entrada se conecta a un garaje y desde la conexión al garaje para una distancia que no exceda de 30' hacia la línea de lote principal.
- Ninguna entrada tendrá más de un corte de bordillo.
- Las entradas circulares están prohibidas.
- Ningún lote tendrá más de una entrada.
- Lotes entre 5.000 y 6000 sf, no más del 65% pueden estar cubiertos por superficies impermeables.
Lotes entre 6.001-8.000 sf, no más del 55%
Lotes 8.001 sf & over, no más del 50%
- Abutting paved o gravel sidewalks or patios considerados como parte de la entrada para determinar la anchura total, el tamaño y el área de entrada.
- Se puede construir una plataforma de aparcamiento pavimentada que no exceda de 12' x 24' adyacente a un garaje en un lote siempre que cumpla con todos los demás requisitos de esta sección.
- Ninguna entrada ubicada en un patio delantero de cualquier lote se extenderá más de 12' a través de la elevación frontal de la residencia ubicada en dicho lote, excepto cuando la entrada se conecta a un garaje adjunto.
- Al enviar el permiso localizar la mejora en su plat de encuesta incluyen dimensiones.
- **Se requiere una inspección previa al vertido. Llame con 24 horas de anticipación para programar. 708-343-8700.**

DRIVEWAYS – PARKING PAD - SIDEWALKS – PATIOS

Submit a completed Building Application along with 2 sets of plans and a plat of survey showing the location of driveway, parking pad, patio or sidewalks to the Building Department.

- When submitting permit locate improvement on your plat of survey include dimensions.
- Concrete driveways must be a minimum of 4" of crushed stone and 5" of concrete.
- Brick pavers must be a minimum of 4" – 6" of crushed stone base, 1" coarse sand, 2 3/8" minimum paver.
- Asphalt must be a minimum of 6" of crushed stone and 2 1/2" – 3" of surface asphalt.
- No driveway shall exceed 24 feet in width except that the width of a driveway may exceed 24 feet at the point that the driveway connects to a garage and from the connection to the garage for a distance not to exceed 30' toward the front lot line.
- No driveway shall have more than one curb cut.
- Circular driveways are prohibited.
- No lot shall have more than one driveway.
- Lots between 5,000 – 6000 sf, no more than 65% may be covered by impervious surfaces.
Lots between 6,001-8,000 sf, no more than 55%
Lots 8,001 sf & over, no more than 50%
- Abutting paved or gravel sidewalks or patios considered as part of driveway for purposes of determining overall width, size and area of driveway.
- A paved parking pad not to exceed 12' x 24' may be constructed adjacent to a garage on a lot provided that it complies with all other requirements of this section.
- No driveway located in a front yard of any lot shall extend more than 12' across the front elevation of the residence located on such lot except when the driveway connects to an attached garage.
- **Pre pour inspection required. Call 24 hours in advance to schedule. 708-343-8700.**

ENTRADAS – ACERAS DE LA PLATAFORMA DE ESTACIONAMIENTO – PATIOS

Envíe una aplicación de construcción completada junto con 2 conjuntos de planes y un plato de estudio que muestra la ubicación de la entrada, el cojín de estacionamiento, el patio o las aceras al Departamento de Construcción.

- Al enviar el permiso localizar la mejora en su plat de encuesta incluyen dimensiones.
- Las entradas de hormigón deben ser un mínimo de 4" de piedra triturada y 5" de hormigón.
- Las pavimentadoras de ladrillo deben ser un mínimo de 4" – 6" de base de piedra triturada, 1" de arena gruesa, 2 3/8" de pavimentación mínima.
- El asfalto debe ser un mínimo de 6" de piedra triturada y 2 1/2" – 3" de asfalto superficial.
- Ninguna entrada excederá los 24 pies de ancho, excepto que la anchura de una entrada puede exceder de 24 pies en el punto en que la entrada se conecta a un garaje y desde la conexión al garaje para una distancia que no exceda de 30' hacia la línea de lote principal.
- Ninguna entrada tendrá más de un corte de bordillo.
- Las entradas circulares están prohibidas.
- Ningún lote tendrá más de una entrada.
- Lotes entre 5.000 y 6000 sf, no más del 65% pueden estar cubiertos por superficies impermeables.
Lotes entre 6.001-8.000 sf, no más del 55%
Lotes 8.001 sf & over, no más del 50%
- Abutting paved o gravel sidewalks or patios considerados como parte de la entrada para determinar la anchura total, el tamaño y el área de entrada.
- Se puede construir una plataforma de aparcamiento pavimentada que no exceda de 12' x 24' adyacente a un garaje en un lote siempre que cumpla con todos los demás requisitos de esta sección.
- Ninguna entrada ubicada en un patio delantero de cualquier lote se extenderá más de 12' a través de la elevación frontal de la residencia ubicada en dicho lote, excepto cuando la entrada se conecta a un garaje adjunto.
- Al enviar el permiso localizar la mejora en su plat de encuesta incluyen dimensiones.
- **Se requiere una inspección previa al vertido. Llame con 24 horas de anticipación para programar. 708-343-8700.**

DRIVEWAYS – PARKING PAD - SIDEWALKS – PATIOS

Submit a completed Building Application along with 2 sets of plans and a plat of survey showing the location of driveway, parking pad, patio or sidewalks to the Building Department.

- When submitting permit locate improvement on your plat of survey include dimensions.
- Concrete driveways must be a minimum of 4" of crushed stone and 5" of concrete.
- Brick pavers must be a minimum of 4" – 6" of crushed stone base, 1" coarse sand, 2 3/8" minimum paver.
- Asphalt must be a minimum of 6" of crushed stone and 2 1/2" – 3" of surface asphalt.
- No driveway shall exceed 24 feet in width except that the width of a driveway may exceed 24 feet at the point that the driveway connects to a garage and from the connection to the garage for a distance not to exceed 30' toward the front lot line.
- No driveway shall have more than one curb cut.
- Circular driveways are prohibited.
- No lot shall have more than one driveway.
- Lots between 5,000 – 6000 sf, no more than 65% may be covered by impervious surfaces.
Lots between 6,001-8,000 sf, no more than 55%
Lots 8,001 sf & over, no more than 50%
- Abutting paved or gravel sidewalks or patios considered as part of driveway for purposes of determining overall width, size and area of driveway.
- A paved parking pad not to exceed 12' x 24' may be constructed adjacent to a garage on a lot provided that it complies with all other requirements of this section.
- No driveway located in a front yard of any lot shall extend more than 12' across the front elevation of the residence located on such lot except when the driveway connects to an attached garage.
- **Pre pour inspection required. Call 24 hours in advance to schedule. 708-343-8700.**

ENTRADAS – ACERAS DE LA PLATAFORMA DE ESTACIONAMIENTO – PATIOS

Envíe una aplicación de construcción completada junto con 2 conjuntos de planes y un plato de estudio que muestra la ubicación de la entrada, el cojín de estacionamiento, el patio o las aceras al Departamento de Construcción.

- Al enviar el permiso localizar la mejora en su plat de encuesta incluyen dimensiones.
- Las entradas de hormigón deben ser un mínimo de 4" de piedra triturada y 5" de hormigón.
- Las pavimentadoras de ladrillo deben ser un mínimo de 4" – 6" de base de piedra triturada, 1" de arena gruesa, 2 3/8" de pavimentación mínima.
- El asfalto debe ser un mínimo de 6" de piedra triturada y 2 1/2" – 3" de asfalto superficial.
- Ninguna entrada excederá los 24 pies de ancho, excepto que la anchura de una entrada puede exceder de 24 pies en el punto en que la entrada se conecta a un garaje y desde la conexión al garaje para una distancia que no exceda de 30' hacia la línea de lote principal.
- Ninguna entrada tendrá más de un corte de bordillo.
- Las entradas circulares están prohibidas.
- Ningún lote tendrá más de una entrada.
- Lotes entre 5.000 y 6000 sf, no más del 65% pueden estar cubiertos por superficies impermeables.
Lotes entre 6.001-8.000 sf, no más del 55%
Lotes 8.001 sf & over, no más del 50%
- Abutting paved o gravel sidewalks or patios considerados como parte de la entrada para determinar la anchura total, el tamaño y el área de entrada.
- Se puede construir una plataforma de aparcamiento pavimentada que no exceda de 12' x 24' adyacente a un garaje en un lote siempre que cumpla con todos los demás requisitos de esta sección.
- Ninguna entrada ubicada en un patio delantero de cualquier lote se extenderá más de 12' a través de la elevación frontal de la residencia ubicada en dicho lote, excepto cuando la entrada se conecta a un garaje adjunto.
- Al enviar el permiso localizar la mejora en su plat de encuesta incluyen dimensiones.
- **Se requiere una inspección previa al vertido. Llame con 24 horas de anticipación para programar. 708-343-8700.**

DRIVEWAYS – PARKING PAD - SIDEWALKS – PATIOS

Submit a completed Building Application along with 2 sets of plans and a plat of survey showing the location of driveway, parking pad, patio or sidewalks to the Building Department.

- When submitting permit locate improvement on your plat of survey include dimensions.
- Concrete driveways must be a minimum of 4" of crushed stone and 5" of concrete.
- Brick pavers must be a minimum of 4" – 6" of crushed stone base, 1" coarse sand, 2 3/8" minimum paver.
- Asphalt must be a minimum of 6" of crushed stone and 2 1/2" – 3" of surface asphalt.
- No driveway shall exceed 24 feet in width except that the width of a driveway may exceed 24 feet at the point that the driveway connects to a garage and from the connection to the garage for a distance not to exceed 30' toward the front lot line.
- No driveway shall have more than one curb cut.
- Circular driveways are prohibited.
- No lot shall have more than one driveway.
- Lots between 5,000 – 6000 sf, no more than 65% may be covered by impervious surfaces.
Lots between 6,001-8,000 sf, no more than 55%
Lots 8,001 sf & over, no more than 50%
- Abutting paved or gravel sidewalks or patios considered as part of driveway for purposes of determining overall width, size and area of driveway.
- A paved parking pad not to exceed 12' x 24' may be constructed adjacent to a garage on a lot provided that it complies with all other requirements of this section.
- No driveway located in a front yard of any lot shall extend more than 12' across the front elevation of the residence located on such lot except when the driveway connects to an attached garage.
- **Pre pour inspection required. Call 24 hours in advance to schedule. 708-343-8700.**

ENTRADAS – ACERAS DE LA PLATAFORMA DE ESTACIONAMIENTO – PATIOS

Envíe una aplicación de construcción completada junto con 2 conjuntos de planes y un plato de estudio que muestra la ubicación de la entrada, el cojín de estacionamiento, el patio o las aceras al Departamento de Construcción.

- Al enviar el permiso localizar la mejora en su plat de encuesta incluyen dimensiones.
- Las entradas de hormigón deben ser un mínimo de 4" de piedra triturada y 5" de hormigón.
- Las pavimentadoras de ladrillo deben ser un mínimo de 4" – 6" de base de piedra triturada, 1" de arena gruesa, 2 3/8" de pavimentación mínima.
- El asfalto debe ser un mínimo de 6" de piedra triturada y 2 1/2" – 3" de asfalto superficial.
- Ninguna entrada excederá los 24 pies de ancho, excepto que la anchura de una entrada puede exceder de 24 pies en el punto en que la entrada se conecta a un garaje y desde la conexión al garaje para una distancia que no exceda de 30' hacia la línea de lote principal.
- Ninguna entrada tendrá más de un corte de bordillo.
- Las entradas circulares están prohibidas.
- Ningún lote tendrá más de una entrada.
- Lotes entre 5.000 y 6000 sf, no más del 65% pueden estar cubiertos por superficies impermeables.
Lotes entre 6.001-8.000 sf, no más del 55%
Lotes 8.001 sf & over, no más del 50%
- Abutting paved o gravel sidewalks or patios considerados como parte de la entrada para determinar la anchura total, el tamaño y el área de entrada.
- Se puede construir una plataforma de aparcamiento pavimentada que no exceda de 12' x 24' adyacente a un garaje en un lote siempre que cumpla con todos los demás requisitos de esta sección.
- Ninguna entrada ubicada en un patio delantero de cualquier lote se extenderá más de 12' a través de la elevación frontal de la residencia ubicada en dicho lote, excepto cuando la entrada se conecta a un garaje adjunto.
- Al enviar el permiso localizar la mejora en su plat de encuesta incluyen dimensiones.
- **Se requiere una inspección previa al vertido. Llame con 24 horas de anticipación para programar. 708-343-8700.**

DRIVEWAYS – PARKING PAD - SIDEWALKS – PATIOS

Submit a completed Building Application along with 2 sets of plans and a plat of survey showing the location of driveway, parking pad, patio or sidewalks to the Building Department.

- When submitting permit locate improvement on your plat of survey include dimensions.
- Concrete driveways must be a minimum of 4" of crushed stone and 5" of concrete.
- Brick pavers must be a minimum of 4" – 6" of crushed stone base, 1" coarse sand, 2 3/8" minimum paver.
- Asphalt must be a minimum of 6" of crushed stone and 2 1/2" – 3" of surface asphalt.
- No driveway shall exceed 24 feet in width except that the width of a driveway may exceed 24 feet at the point that the driveway connects to a garage and from the connection to the garage for a distance not to exceed 30' toward the front lot line.
- No driveway shall have more than one curb cut.
- Circular driveways are prohibited.
- No lot shall have more than one driveway.
- Lots between 5,000 – 6000 sf, no more than 65% may be covered by impervious surfaces.
Lots between 6,001-8,000 sf, no more than 55%
Lots 8,001 sf & over, no more than 50%
- Abutting paved or gravel sidewalks or patios considered as part of driveway for purposes of determining overall width, size and area of driveway.
- A paved parking pad not to exceed 12' x 24' may be constructed adjacent to a garage on a lot provided that it complies with all other requirements of this section.
- No driveway located in a front yard of any lot shall extend more than 12' across the front elevation of the residence located on such lot except when the driveway connects to an attached garage.
- **Pre pour inspection required. Call 24 hours in advance to schedule. 708-343-8700.**

ENTRADAS – ACERAS DE LA PLATAFORMA DE ESTACIONAMIENTO – PATIOS

Envíe una aplicación de construcción completada junto con 2 conjuntos de planes y un plato de estudio que muestra la ubicación de la entrada, el cojín de estacionamiento, el patio o las aceras al Departamento de Construcción.

- Al enviar el permiso localizar la mejora en su plat de encuesta incluyen dimensiones.
- Las entradas de hormigón deben ser un mínimo de 4" de piedra triturada y 5" de hormigón.
- Las pavimentadoras de ladrillo deben ser un mínimo de 4" – 6" de base de piedra triturada, 1" de arena gruesa, 2 3/8" de pavimentación mínima.
- El asfalto debe ser un mínimo de 6" de piedra triturada y 2 1/2" – 3" de asfalto superficial.
- Ninguna entrada excederá los 24 pies de ancho, excepto que la anchura de una entrada puede exceder de 24 pies en el punto en que la entrada se conecta a un garaje y desde la conexión al garaje para una distancia que no exceda de 30' hacia la línea de lote principal.
- Ninguna entrada tendrá más de un corte de bordillo.
- Las entradas circulares están prohibidas.
- Ningún lote tendrá más de una entrada.
- Lotes entre 5.000 y 6000 sf, no más del 65% pueden estar cubiertos por superficies impermeables.
Lotes entre 6.001-8.000 sf, no más del 55%
Lotes 8.001 sf & over, no más del 50%
- Abutting paved o gravel sidewalks or patios considerados como parte de la entrada para determinar la anchura total, el tamaño y el área de entrada.
- Se puede construir una plataforma de aparcamiento pavimentada que no exceda de 12' x 24' adyacente a un garaje en un lote siempre que cumpla con todos los demás requisitos de esta sección.
- Ninguna entrada ubicada en un patio delantero de cualquier lote se extenderá más de 12' a través de la elevación frontal de la residencia ubicada en dicho lote, excepto cuando la entrada se conecta a un garaje adjunto.
- Al enviar el permiso localizar la mejora en su plat de encuesta incluyen dimensiones.
- **Se requiere una inspección previa al vertido. Llame con 24 horas de anticipación para programar. 708-343-8700.**

DRIVEWAYS – PARKING PAD - SIDEWALKS – PATIOS

Submit a completed Building Application along with 2 sets of plans and a plat of survey showing the location of driveway, parking pad, patio or sidewalks to the Building Department.

- When submitting permit locate improvement on your plat of survey include dimensions.
- Concrete driveways must be a minimum of 4" of crushed stone and 5" of concrete.
- Brick pavers must be a minimum of 4" – 6" of crushed stone base, 1" coarse sand, 2 3/8" minimum paver.
- Asphalt must be a minimum of 6" of crushed stone and 2 1/2" – 3" of surface asphalt.
- No driveway shall exceed 24 feet in width except that the width of a driveway may exceed 24 feet at the point that the driveway connects to a garage and from the connection to the garage for a distance not to exceed 30' toward the front lot line.
- No driveway shall have more than one curb cut.
- Circular driveways are prohibited.
- No lot shall have more than one driveway.
- Lots between 5,000 – 6000 sf, no more than 65% may be covered by impervious surfaces.
Lots between 6,001-8,000 sf, no more than 55%
Lots 8,001 sf & over, no more than 50%
- Abutting paved or gravel sidewalks or patios considered as part of driveway for purposes of determining overall width, size and area of driveway.
- A paved parking pad not to exceed 12' x 24' may be constructed adjacent to a garage on a lot provided that it complies with all other requirements of this section.
- No driveway located in a front yard of any lot shall extend more than 12' across the front elevation of the residence located on such lot except when the driveway connects to an attached garage.
- **Pre pour inspection required. Call 24 hours in advance to schedule. 708-343-8700.**

ENTRADAS – ACERAS DE LA PLATAFORMA DE ESTACIONAMIENTO – PATIOS

Envíe una aplicación de construcción completada junto con 2 conjuntos de planes y un plato de estudio que muestra la ubicación de la entrada, el cojín de estacionamiento, el patio o las aceras al Departamento de Construcción.

- Al enviar el permiso localizar la mejora en su plat de encuesta incluyen dimensiones.
- Las entradas de hormigón deben ser un mínimo de 4" de piedra triturada y 5" de hormigón.
- Las pavimentadoras de ladrillo deben ser un mínimo de 4" – 6" de base de piedra triturada, 1" de arena gruesa, 2 3/8" de pavimentación mínima.
- El asfalto debe ser un mínimo de 6" de piedra triturada y 2 1/2" – 3" de asfalto superficial.
- Ninguna entrada excederá los 24 pies de ancho, excepto que la anchura de una entrada puede exceder de 24 pies en el punto en que la entrada se conecta a un garaje y desde la conexión al garaje para una distancia que no exceda de 30' hacia la línea de lote principal.
- Ninguna entrada tendrá más de un corte de bordillo.
- Las entradas circulares están prohibidas.
- Ningún lote tendrá más de una entrada.
- Lotes entre 5.000 y 6000 sf, no más del 65% pueden estar cubiertos por superficies impermeables.
Lotes entre 6.001-8.000 sf, no más del 55%
Lotes 8.001 sf & over, no más del 50%
- Abutting paved o gravel sidewalks or patios considerados como parte de la entrada para determinar la anchura total, el tamaño y el área de entrada.
- Se puede construir una plataforma de aparcamiento pavimentada que no exceda de 12' x 24' adyacente a un garaje en un lote siempre que cumpla con todos los demás requisitos de esta sección.
- Ninguna entrada ubicada en un patio delantero de cualquier lote se extenderá más de 12' a través de la elevación frontal de la residencia ubicada en dicho lote, excepto cuando la entrada se conecta a un garaje adjunto.
- Al enviar el permiso localizar la mejora en su plat de encuesta incluyen dimensiones.
- **Se requiere una inspección previa al vertido. Llame con 24 horas de anticipación para programar. 708-343-8700.**

DRIVEWAYS – PARKING PAD - SIDEWALKS – PATIOS

Submit a completed Building Application along with 2 sets of plans and a plat of survey showing the location of driveway, parking pad, patio or sidewalks to the Building Department.

- When submitting permit locate improvement on your plat of survey include dimensions.
- Concrete driveways must be a minimum of 4" of crushed stone and 5" of concrete.
- Brick pavers must be a minimum of 4" – 6" of crushed stone base, 1" coarse sand, 2 3/8" minimum paver.
- Asphalt must be a minimum of 6" of crushed stone and 2 1/2" – 3" of surface asphalt.
- No driveway shall exceed 24 feet in width except that the width of a driveway may exceed 24 feet at the point that the driveway connects to a garage and from the connection to the garage for a distance not to exceed 30' toward the front lot line.
- No driveway shall have more than one curb cut.
- Circular driveways are prohibited.
- No lot shall have more than one driveway.
- Lots between 5,000 – 6000 sf, no more than 65% may be covered by impervious surfaces.
Lots between 6,001-8,000 sf, no more than 55%
Lots 8,001 sf & over, no more than 50%
- Abutting paved or gravel sidewalks or patios considered as part of driveway for purposes of determining overall width, size and area of driveway.
- A paved parking pad not to exceed 12' x 24' may be constructed adjacent to a garage on a lot provided that it complies with all other requirements of this section.
- No driveway located in a front yard of any lot shall extend more than 12' across the front elevation of the residence located on such lot except when the driveway connects to an attached garage.
- **Pre pour inspection required. Call 24 hours in advance to schedule. 708-343-8700.**

ENTRADAS – ACERAS DE LA PLATAFORMA DE ESTACIONAMIENTO – PATIOS

Envíe una aplicación de construcción completada junto con 2 conjuntos de planes y un plato de estudio que muestra la ubicación de la entrada, el cojín de estacionamiento, el patio o las aceras al Departamento de Construcción.

- Al enviar el permiso localizar la mejora en su plat de encuesta incluyen dimensiones.
- Las entradas de hormigón deben ser un mínimo de 4" de piedra triturada y 5" de hormigón.
- Las pavimentadoras de ladrillo deben ser un mínimo de 4" – 6" de base de piedra triturada, 1" de arena gruesa, 2 3/8" de pavimentación mínima.
- El asfalto debe ser un mínimo de 6" de piedra triturada y 2 1/2" – 3" de asfalto superficial.
- Ninguna entrada excederá los 24 pies de ancho, excepto que la anchura de una entrada puede exceder de 24 pies en el punto en que la entrada se conecta a un garaje y desde la conexión al garaje para una distancia que no exceda de 30' hacia la línea de lote principal.
- Ninguna entrada tendrá más de un corte de bordillo.
- Las entradas circulares están prohibidas.
- Ningún lote tendrá más de una entrada.
- Lotes entre 5.000 y 6000 sf, no más del 65% pueden estar cubiertos por superficies impermeables.
Lotes entre 6.001-8.000 sf, no más del 55%
Lotes 8.001 sf & over, no más del 50%
- Abutting paved o gravel sidewalks or patios considerados como parte de la entrada para determinar la anchura total, el tamaño y el área de entrada.
- Se puede construir una plataforma de aparcamiento pavimentada que no exceda de 12' x 24' adyacente a un garaje en un lote siempre que cumpla con todos los demás requisitos de esta sección.
- Ninguna entrada ubicada en un patio delantero de cualquier lote se extenderá más de 12' a través de la elevación frontal de la residencia ubicada en dicho lote, excepto cuando la entrada se conecta a un garaje adjunto.
- Al enviar el permiso localizar la mejora en su plat de encuesta incluyen dimensiones.
- **Se requiere una inspección previa al vertido. Llame con 24 horas de anticipación para programar. 708-343-8700.**

DRIVEWAYS – PARKING PAD - SIDEWALKS – PATIOS

Submit a completed Building Application along with 2 sets of plans and a plat of survey showing the location of driveway, parking pad, patio or sidewalks to the Building Department.

- When submitting permit locate improvement on your plat of survey include dimensions.
- Concrete driveways must be a minimum of 4" of crushed stone and 5" of concrete.
- Brick pavers must be a minimum of 4" – 6" of crushed stone base, 1" coarse sand, 2 3/8" minimum paver.
- Asphalt must be a minimum of 6" of crushed stone and 2 1/2" – 3" of surface asphalt.
- No driveway shall exceed 24 feet in width except that the width of a driveway may exceed 24 feet at the point that the driveway connects to a garage and from the connection to the garage for a distance not to exceed 30' toward the front lot line.
- No driveway shall have more than one curb cut.
- Circular driveways are prohibited.
- No lot shall have more than one driveway.
- Lots between 5,000 – 6000 sf, no more than 65% may be covered by impervious surfaces.
Lots between 6,001-8,000 sf, no more than 55%
Lots 8,001 sf & over, no more than 50%
- Abutting paved or gravel sidewalks or patios considered as part of driveway for purposes of determining overall width, size and area of driveway.
- A paved parking pad not to exceed 12' x 24' may be constructed adjacent to a garage on a lot provided that it complies with all other requirements of this section.
- No driveway located in a front yard of any lot shall extend more than 12' across the front elevation of the residence located on such lot except when the driveway connects to an attached garage.
- **Pre pour inspection required. Call 24 hours in advance to schedule. 708-343-8700.**

ENTRADAS – ACERAS DE LA PLATAFORMA DE ESTACIONAMIENTO – PATIOS

Envíe una aplicación de construcción completada junto con 2 conjuntos de planes y un plato de estudio que muestra la ubicación de la entrada, el cojín de estacionamiento, el patio o las aceras al Departamento de Construcción.

- Al enviar el permiso localizar la mejora en su plat de encuesta incluyen dimensiones.
- Las entradas de hormigón deben ser un mínimo de 4" de piedra triturada y 5" de hormigón.
- Las pavimentadoras de ladrillo deben ser un mínimo de 4" – 6" de base de piedra triturada, 1" de arena gruesa, 2 3/8" de pavimentación mínima.
- El asfalto debe ser un mínimo de 6" de piedra triturada y 2 1/2" – 3" de asfalto superficial.
- Ninguna entrada excederá los 24 pies de ancho, excepto que la anchura de una entrada puede exceder de 24 pies en el punto en que la entrada se conecta a un garaje y desde la conexión al garaje para una distancia que no exceda de 30' hacia la línea de lote principal.
- Ninguna entrada tendrá más de un corte de bordillo.
- Las entradas circulares están prohibidas.
- Ningún lote tendrá más de una entrada.
- Lotes entre 5.000 y 6000 sf, no más del 65% pueden estar cubiertos por superficies impermeables.
Lotes entre 6.001-8.000 sf, no más del 55%
Lotes 8.001 sf & over, no más del 50%
- Abutting paved o gravel sidewalks or patios considerados como parte de la entrada para determinar la anchura total, el tamaño y el área de entrada.
- Se puede construir una plataforma de aparcamiento pavimentada que no exceda de 12' x 24' adyacente a un garaje en un lote siempre que cumpla con todos los demás requisitos de esta sección.
- Ninguna entrada ubicada en un patio delantero de cualquier lote se extenderá más de 12' a través de la elevación frontal de la residencia ubicada en dicho lote, excepto cuando la entrada se conecta a un garaje adjunto.
- Al enviar el permiso localizar la mejora en su plat de encuesta incluyen dimensiones.
- **Se requiere una inspección previa al vertido. Llame con 24 horas de anticipación para programar. 708-343-8700.**

DRIVEWAYS – PARKING PAD - SIDEWALKS – PATIOS

Submit a completed Building Application along with 2 sets of plans and a plat of survey showing the location of driveway, parking pad, patio or sidewalks to the Building Department.

- When submitting permit locate improvement on your plat of survey include dimensions.
- Concrete driveways must be a minimum of 4" of crushed stone and 5" of concrete.
- Brick pavers must be a minimum of 4" – 6" of crushed stone base, 1" coarse sand, 2 3/8" minimum paver.
- Asphalt must be a minimum of 6" of crushed stone and 2 1/2" – 3" of surface asphalt.
- No driveway shall exceed 24 feet in width except that the width of a driveway may exceed 24 feet at the point that the driveway connects to a garage and from the connection to the garage for a distance not to exceed 30' toward the front lot line.
- No driveway shall have more than one curb cut.
- Circular driveways are prohibited.
- No lot shall have more than one driveway.
- Lots between 5,000 – 6000 sf, no more than 65% may be covered by impervious surfaces.
Lots between 6,001-8,000 sf, no more than 55%
Lots 8,001 sf & over, no more than 50%
- Abutting paved or gravel sidewalks or patios considered as part of driveway for purposes of determining overall width, size and area of driveway.
- A paved parking pad not to exceed 12' x 24' may be constructed adjacent to a garage on a lot provided that it complies with all other requirements of this section.
- No driveway located in a front yard of any lot shall extend more than 12' across the front elevation of the residence located on such lot except when the driveway connects to an attached garage.
- **Pre pour inspection required. Call 24 hours in advance to schedule. 708-343-8700.**

ENTRADAS – ACERAS DE LA PLATAFORMA DE ESTACIONAMIENTO – PATIOS

Envíe una aplicación de construcción completada junto con 2 conjuntos de planes y un plato de estudio que muestra la ubicación de la entrada, el cojín de estacionamiento, el patio o las aceras al Departamento de Construcción.

- Al enviar el permiso localizar la mejora en su plat de encuesta incluyen dimensiones.
- Las entradas de hormigón deben ser un mínimo de 4" de piedra triturada y 5" de hormigón.
- Las pavimentadoras de ladrillo deben ser un mínimo de 4" – 6" de base de piedra triturada, 1" de arena gruesa, 2 3/8" de pavimentación mínima.
- El asfalto debe ser un mínimo de 6" de piedra triturada y 2 1/2" – 3" de asfalto superficial.
- Ninguna entrada excederá los 24 pies de ancho, excepto que la anchura de una entrada puede exceder de 24 pies en el punto en que la entrada se conecta a un garaje y desde la conexión al garaje para una distancia que no exceda de 30' hacia la línea de lote principal.
- Ninguna entrada tendrá más de un corte de bordillo.
- Las entradas circulares están prohibidas.
- Ningún lote tendrá más de una entrada.
- Lotes entre 5.000 y 6000 sf, no más del 65% pueden estar cubiertos por superficies impermeables.
Lotes entre 6.001-8.000 sf, no más del 55%
Lotes 8.001 sf & over, no más del 50%
- Abutting paved o gravel sidewalks or patios considerados como parte de la entrada para determinar la anchura total, el tamaño y el área de entrada.
- Se puede construir una plataforma de aparcamiento pavimentada que no exceda de 12' x 24' adyacente a un garaje en un lote siempre que cumpla con todos los demás requisitos de esta sección.
- Ninguna entrada ubicada en un patio delantero de cualquier lote se extenderá más de 12' a través de la elevación frontal de la residencia ubicada en dicho lote, excepto cuando la entrada se conecta a un garaje adjunto.
- Al enviar el permiso localizar la mejora en su plat de encuesta incluyen dimensiones.
- **Se requiere una inspección previa al vertido. Llame con 24 horas de anticipación para programar. 708-343-8700.**

DRIVEWAYS – PARKING PAD - SIDEWALKS – PATIOS

Submit a completed Building Application along with 2 sets of plans and a plat of survey showing the location of driveway, parking pad, patio or sidewalks to the Building Department.

- When submitting permit locate improvement on your plat of survey include dimensions.
- Concrete driveways must be a minimum of 4" of crushed stone and 5" of concrete.
- Brick pavers must be a minimum of 4" – 6" of crushed stone base, 1" coarse sand, 2 3/8" minimum paver.
- Asphalt must be a minimum of 6" of crushed stone and 2 1/2" – 3" of surface asphalt.
- No driveway shall exceed 24 feet in width except that the width of a driveway may exceed 24 feet at the point that the driveway connects to a garage and from the connection to the garage for a distance not to exceed 30' toward the front lot line.
- No driveway shall have more than one curb cut.
- Circular driveways are prohibited.
- No lot shall have more than one driveway.
- Lots between 5,000 – 6000 sf, no more than 65% may be covered by impervious surfaces.
Lots between 6,001-8,000 sf, no more than 55%
Lots 8,001 sf & over, no more than 50%
- Abutting paved or gravel sidewalks or patios considered as part of driveway for purposes of determining overall width, size and area of driveway.
- A paved parking pad not to exceed 12' x 24' may be constructed adjacent to a garage on a lot provided that it complies with all other requirements of this section.
- No driveway located in a front yard of any lot shall extend more than 12' across the front elevation of the residence located on such lot except when the driveway connects to an attached garage.
- **Pre pour inspection required. Call 24 hours in advance to schedule. 708-343-8700.**

ENTRADAS – ACERAS DE LA PLATAFORMA DE ESTACIONAMIENTO – PATIOS

Envíe una aplicación de construcción completada junto con 2 conjuntos de planes y un plato de estudio que muestra la ubicación de la entrada, el cojín de estacionamiento, el patio o las aceras al Departamento de Construcción.

- Al enviar el permiso localizar la mejora en su plat de encuesta incluyen dimensiones.
- Las entradas de hormigón deben ser un mínimo de 4" de piedra triturada y 5" de hormigón.
- Las pavimentadoras de ladrillo deben ser un mínimo de 4" – 6" de base de piedra triturada, 1" de arena gruesa, 2 3/8" de pavimentación mínima.
- El asfalto debe ser un mínimo de 6" de piedra triturada y 2 1/2" – 3" de asfalto superficial.
- Ninguna entrada excederá los 24 pies de ancho, excepto que la anchura de una entrada puede exceder de 24 pies en el punto en que la entrada se conecta a un garaje y desde la conexión al garaje para una distancia que no exceda de 30' hacia la línea de lote principal.
- Ninguna entrada tendrá más de un corte de bordillo.
- Las entradas circulares están prohibidas.
- Ningún lote tendrá más de una entrada.
- Lotes entre 5.000 y 6000 sf, no más del 65% pueden estar cubiertos por superficies impermeables.
Lotes entre 6.001-8.000 sf, no más del 55%
Lotes 8.001 sf & over, no más del 50%
- Abutting paved o gravel sidewalks or patios considerados como parte de la entrada para determinar la anchura total, el tamaño y el área de entrada.
- Se puede construir una plataforma de aparcamiento pavimentada que no exceda de 12' x 24' adyacente a un garaje en un lote siempre que cumpla con todos los demás requisitos de esta sección.
- Ninguna entrada ubicada en un patio delantero de cualquier lote se extenderá más de 12' a través de la elevación frontal de la residencia ubicada en dicho lote, excepto cuando la entrada se conecta a un garaje adjunto.
- Al enviar el permiso localizar la mejora en su plat de encuesta incluyen dimensiones.
- **Se requiere una inspección previa al vertido. Llame con 24 horas de anticipación para programar. 708-343-8700.**

DRIVEWAYS – PARKING PAD - SIDEWALKS – PATIOS

Submit a completed Building Application along with 2 sets of plans and a plat of survey showing the location of driveway, parking pad, patio or sidewalks to the Building Department.

- When submitting permit locate improvement on your plat of survey include dimensions.
- Concrete driveways must be a minimum of 4" of crushed stone and 5" of concrete.
- Brick pavers must be a minimum of 4" – 6" of crushed stone base, 1" coarse sand, 2 3/8" minimum paver.
- Asphalt must be a minimum of 6" of crushed stone and 2 1/2" – 3" of surface asphalt.
- No driveway shall exceed 24 feet in width except that the width of a driveway may exceed 24 feet at the point that the driveway connects to a garage and from the connection to the garage for a distance not to exceed 30' toward the front lot line.
- No driveway shall have more than one curb cut.
- Circular driveways are prohibited.
- No lot shall have more than one driveway.
- Lots between 5,000 – 6000 sf, no more than 65% may be covered by impervious surfaces.
Lots between 6,001-8,000 sf, no more than 55%
Lots 8,001 sf & over, no more than 50%
- Abutting paved or gravel sidewalks or patios considered as part of driveway for purposes of determining overall width, size and area of driveway.
- A paved parking pad not to exceed 12' x 24' may be constructed adjacent to a garage on a lot provided that it complies with all other requirements of this section.
- No driveway located in a front yard of any lot shall extend more than 12' across the front elevation of the residence located on such lot except when the driveway connects to an attached garage.
- **Pre pour inspection required. Call 24 hours in advance to schedule. 708-343-8700.**

ENTRADAS – ACERAS DE LA PLATAFORMA DE ESTACIONAMIENTO – PATIOS

Envíe una aplicación de construcción completada junto con 2 conjuntos de planes y un plato de estudio que muestra la ubicación de la entrada, el cojín de estacionamiento, el patio o las aceras al Departamento de Construcción.

- Al enviar el permiso localizar la mejora en su plat de encuesta incluyen dimensiones.
- Las entradas de hormigón deben ser un mínimo de 4" de piedra triturada y 5" de hormigón.
- Las pavimentadoras de ladrillo deben ser un mínimo de 4" – 6" de base de piedra triturada, 1" de arena gruesa, 2 3/8" de pavimentación mínima.
- El asfalto debe ser un mínimo de 6" de piedra triturada y 2 1/2" – 3" de asfalto superficial.
- Ninguna entrada excederá los 24 pies de ancho, excepto que la anchura de una entrada puede exceder de 24 pies en el punto en que la entrada se conecta a un garaje y desde la conexión al garaje para una distancia que no exceda de 30' hacia la línea de lote principal.
- Ninguna entrada tendrá más de un corte de bordillo.
- Las entradas circulares están prohibidas.
- Ningún lote tendrá más de una entrada.
- Lotes entre 5.000 y 6000 sf, no más del 65% pueden estar cubiertos por superficies impermeables.
Lotes entre 6.001-8.000 sf, no más del 55%
Lotes 8.001 sf & over, no más del 50%
- Abutting paved o gravel sidewalks or patios considerados como parte de la entrada para determinar la anchura total, el tamaño y el área de entrada.
- Se puede construir una plataforma de aparcamiento pavimentada que no exceda de 12' x 24' adyacente a un garaje en un lote siempre que cumpla con todos los demás requisitos de esta sección.
- Ninguna entrada ubicada en un patio delantero de cualquier lote se extenderá más de 12' a través de la elevación frontal de la residencia ubicada en dicho lote, excepto cuando la entrada se conecta a un garaje adjunto.
- Al enviar el permiso localizar la mejora en su plat de encuesta incluyen dimensiones.
- **Se requiere una inspección previa al vertido. Llame con 24 horas de anticipación para programar. 708-343-8700.**

DRIVEWAYS – PARKING PAD - SIDEWALKS – PATIOS

Submit a completed Building Application along with 2 sets of plans and a plat of survey showing the location of driveway, parking pad, patio or sidewalks to the Building Department.

- When submitting permit locate improvement on your plat of survey include dimensions.
- Concrete driveways must be a minimum of 4" of crushed stone and 5" of concrete.
- Brick pavers must be a minimum of 4" – 6" of crushed stone base, 1" coarse sand, 2 3/8" minimum paver.
- Asphalt must be a minimum of 6" of crushed stone and 2 1/2" – 3" of surface asphalt.
- No driveway shall exceed 24 feet in width except that the width of a driveway may exceed 24 feet at the point that the driveway connects to a garage and from the connection to the garage for a distance not to exceed 30' toward the front lot line.
- No driveway shall have more than one curb cut.
- Circular driveways are prohibited.
- No lot shall have more than one driveway.
- Lots between 5,000 – 6000 sf, no more than 65% may be covered by impervious surfaces.
Lots between 6,001-8,000 sf, no more than 55%
Lots 8,001 sf & over, no more than 50%
- Abutting paved or gravel sidewalks or patios considered as part of driveway for purposes of determining overall width, size and area of driveway.
- A paved parking pad not to exceed 12' x 24' may be constructed adjacent to a garage on a lot provided that it complies with all other requirements of this section.
- No driveway located in a front yard of any lot shall extend more than 12' across the front elevation of the residence located on such lot except when the driveway connects to an attached garage.
- **Pre pour inspection required. Call 24 hours in advance to schedule. 708-343-8700.**

ENTRADAS – ACERAS DE LA PLATAFORMA DE ESTACIONAMIENTO – PATIOS

Envíe una aplicación de construcción completada junto con 2 conjuntos de planes y un plato de estudio que muestra la ubicación de la entrada, el cojín de estacionamiento, el patio o las aceras al Departamento de Construcción.

- Al enviar el permiso localizar la mejora en su plat de encuesta incluyen dimensiones.
- Las entradas de hormigón deben ser un mínimo de 4" de piedra triturada y 5" de hormigón.
- Las pavimentadoras de ladrillo deben ser un mínimo de 4" – 6" de base de piedra triturada, 1" de arena gruesa, 2 3/8" de pavimentación mínima.
- El asfalto debe ser un mínimo de 6" de piedra triturada y 2 1/2" – 3" de asfalto superficial.
- Ninguna entrada excederá los 24 pies de ancho, excepto que la anchura de una entrada puede exceder de 24 pies en el punto en que la entrada se conecta a un garaje y desde la conexión al garaje para una distancia que no exceda de 30' hacia la línea de lote principal.
- Ninguna entrada tendrá más de un corte de bordillo.
- Las entradas circulares están prohibidas.
- Ningún lote tendrá más de una entrada.
- Lotes entre 5.000 y 6000 sf, no más del 65% pueden estar cubiertos por superficies impermeables.
Lotes entre 6.001-8.000 sf, no más del 55%
Lotes 8.001 sf & over, no más del 50%
- Abutting paved o gravel sidewalks or patios considerados como parte de la entrada para determinar la anchura total, el tamaño y el área de entrada.
- Se puede construir una plataforma de aparcamiento pavimentada que no exceda de 12' x 24' adyacente a un garaje en un lote siempre que cumpla con todos los demás requisitos de esta sección.
- Ninguna entrada ubicada en un patio delantero de cualquier lote se extenderá más de 12' a través de la elevación frontal de la residencia ubicada en dicho lote, excepto cuando la entrada se conecta a un garaje adjunto.
- Al enviar el permiso localizar la mejora en su plat de encuesta incluyen dimensiones.
- **Se requiere una inspección previa al vertido. Llame con 24 horas de anticipación para programar. 708-343-8700.**

DRIVEWAYS – PARKING PAD - SIDEWALKS – PATIOS

Submit a completed Building Application along with 2 sets of plans and a plat of survey showing the location of driveway, parking pad, patio or sidewalks to the Building Department.

- When submitting permit locate improvement on your plat of survey include dimensions.
- Concrete driveways must be a minimum of 4" of crushed stone and 5" of concrete.
- Brick pavers must be a minimum of 4" – 6" of crushed stone base, 1" coarse sand, 2 3/8" minimum paver.
- Asphalt must be a minimum of 6" of crushed stone and 2 1/2" – 3" of surface asphalt.
- No driveway shall exceed 24 feet in width except that the width of a driveway may exceed 24 feet at the point that the driveway connects to a garage and from the connection to the garage for a distance not to exceed 30' toward the front lot line.
- No driveway shall have more than one curb cut.
- Circular driveways are prohibited.
- No lot shall have more than one driveway.
- Lots between 5,000 – 6000 sf, no more than 65% may be covered by impervious surfaces.
Lots between 6,001-8,000 sf, no more than 55%
Lots 8,001 sf & over, no more than 50%
- Abutting paved or gravel sidewalks or patios considered as part of driveway for purposes of determining overall width, size and area of driveway.
- A paved parking pad not to exceed 12' x 24' may be constructed adjacent to a garage on a lot provided that it complies with all other requirements of this section.
- No driveway located in a front yard of any lot shall extend more than 12' across the front elevation of the residence located on such lot except when the driveway connects to an attached garage.
- **Pre pour inspection required. Call 24 hours in advance to schedule. 708-343-8700.**

ENTRADAS – ACERAS DE LA PLATAFORMA DE ESTACIONAMIENTO – PATIOS

Envíe una aplicación de construcción completada junto con 2 conjuntos de planes y un plato de estudio que muestra la ubicación de la entrada, el cojín de estacionamiento, el patio o las aceras al Departamento de Construcción.

- Al enviar el permiso localizar la mejora en su plat de encuesta incluyen dimensiones.
- Las entradas de hormigón deben ser un mínimo de 4" de piedra triturada y 5" de hormigón.
- Las pavimentadoras de ladrillo deben ser un mínimo de 4" – 6" de base de piedra triturada, 1" de arena gruesa, 2 3/8" de pavimentación mínima.
- El asfalto debe ser un mínimo de 6" de piedra triturada y 2 1/2" – 3" de asfalto superficial.
- Ninguna entrada excederá los 24 pies de ancho, excepto que la anchura de una entrada puede exceder de 24 pies en el punto en que la entrada se conecta a un garaje y desde la conexión al garaje para una distancia que no exceda de 30' hacia la línea de lote principal.
- Ninguna entrada tendrá más de un corte de bordillo.
- Las entradas circulares están prohibidas.
- Ningún lote tendrá más de una entrada.
- Lotes entre 5.000 y 6000 sf, no más del 65% pueden estar cubiertos por superficies impermeables.
Lotes entre 6.001-8.000 sf, no más del 55%
Lotes 8.001 sf & over, no más del 50%
- Abutting paved o gravel sidewalks or patios considerados como parte de la entrada para determinar la anchura total, el tamaño y el área de entrada.
- Se puede construir una plataforma de aparcamiento pavimentada que no exceda de 12' x 24' adyacente a un garaje en un lote siempre que cumpla con todos los demás requisitos de esta sección.
- Ninguna entrada ubicada en un patio delantero de cualquier lote se extenderá más de 12' a través de la elevación frontal de la residencia ubicada en dicho lote, excepto cuando la entrada se conecta a un garaje adjunto.
- Al enviar el permiso localizar la mejora en su plat de encuesta incluyen dimensiones.
- **Se requiere una inspección previa al vertido. Llame con 24 horas de anticipación para programar. 708-343-8700.**

DRIVEWAYS – PARKING PAD - SIDEWALKS – PATIOS

Submit a completed Building Application along with 2 sets of plans and a plat of survey showing the location of driveway, parking pad, patio or sidewalks to the Building Department.

- When submitting permit locate improvement on your plat of survey include dimensions.
- Concrete driveways must be a minimum of 4" of crushed stone and 5" of concrete.
- Brick pavers must be a minimum of 4" – 6" of crushed stone base, 1" coarse sand, 2 3/8" minimum paver.
- Asphalt must be a minimum of 6" of crushed stone and 2 1/2" – 3" of surface asphalt.
- No driveway shall exceed 24 feet in width except that the width of a driveway may exceed 24 feet at the point that the driveway connects to a garage and from the connection to the garage for a distance not to exceed 30' toward the front lot line.
- No driveway shall have more than one curb cut.
- Circular driveways are prohibited.
- No lot shall have more than one driveway.
- Lots between 5,000 – 6000 sf, no more than 65% may be covered by impervious surfaces.
Lots between 6,001-8,000 sf, no more than 55%
Lots 8,001 sf & over, no more than 50%
- Abutting paved or gravel sidewalks or patios considered as part of driveway for purposes of determining overall width, size and area of driveway.
- A paved parking pad not to exceed 12' x 24' may be constructed adjacent to a garage on a lot provided that it complies with all other requirements of this section.
- No driveway located in a front yard of any lot shall extend more than 12' across the front elevation of the residence located on such lot except when the driveway connects to an attached garage.
- **Pre pour inspection required. Call 24 hours in advance to schedule. 708-343-8700.**

ENTRADAS – ACERAS DE LA PLATAFORMA DE ESTACIONAMIENTO – PATIOS

Envíe una aplicación de construcción completada junto con 2 conjuntos de planes y un plato de estudio que muestra la ubicación de la entrada, el cojín de estacionamiento, el patio o las aceras al Departamento de Construcción.

- Al enviar el permiso localizar la mejora en su plat de encuesta incluyen dimensiones.
- Las entradas de hormigón deben ser un mínimo de 4" de piedra triturada y 5" de hormigón.
- Las pavimentadoras de ladrillo deben ser un mínimo de 4" – 6" de base de piedra triturada, 1" de arena gruesa, 2 3/8" de pavimentación mínima.
- El asfalto debe ser un mínimo de 6" de piedra triturada y 2 1/2" – 3" de asfalto superficial.
- Ninguna entrada excederá los 24 pies de ancho, excepto que la anchura de una entrada puede exceder de 24 pies en el punto en que la entrada se conecta a un garaje y desde la conexión al garaje para una distancia que no exceda de 30' hacia la línea de lote principal.
- Ninguna entrada tendrá más de un corte de bordillo.
- Las entradas circulares están prohibidas.
- Ningún lote tendrá más de una entrada.
- Lotes entre 5.000 y 6000 sf, no más del 65% pueden estar cubiertos por superficies impermeables.
Lotes entre 6.001-8.000 sf, no más del 55%
Lotes 8.001 sf & over, no más del 50%
- Abutting paved o gravel sidewalks or patios considerados como parte de la entrada para determinar la anchura total, el tamaño y el área de entrada.
- Se puede construir una plataforma de aparcamiento pavimentada que no exceda de 12' x 24' adyacente a un garaje en un lote siempre que cumpla con todos los demás requisitos de esta sección.
- Ninguna entrada ubicada en un patio delantero de cualquier lote se extenderá más de 12' a través de la elevación frontal de la residencia ubicada en dicho lote, excepto cuando la entrada se conecta a un garaje adjunto.
- Al enviar el permiso localizar la mejora en su plat de encuesta incluyen dimensiones.
- **Se requiere una inspección previa al vertido. Llame con 24 horas de anticipación para programar. 708-343-8700.**

DRIVEWAYS – PARKING PAD - SIDEWALKS – PATIOS

Submit a completed Building Application along with 2 sets of plans and a plat of survey showing the location of driveway, parking pad, patio or sidewalks to the Building Department.

- When submitting permit locate improvement on your plat of survey include dimensions.
- Concrete driveways must be a minimum of 4" of crushed stone and 5" of concrete.
- Brick pavers must be a minimum of 4" – 6" of crushed stone base, 1" coarse sand, 2 3/8" minimum paver.
- Asphalt must be a minimum of 6" of crushed stone and 2 1/2" – 3" of surface asphalt.
- No driveway shall exceed 24 feet in width except that the width of a driveway may exceed 24 feet at the point that the driveway connects to a garage and from the connection to the garage for a distance not to exceed 30' toward the front lot line.
- No driveway shall have more than one curb cut.
- Circular driveways are prohibited.
- No lot shall have more than one driveway.
- Lots between 5,000 – 6000 sf, no more than 65% may be covered by impervious surfaces.
Lots between 6,001-8,000 sf, no more than 55%
Lots 8,001 sf & over, no more than 50%
- Abutting paved or gravel sidewalks or patios considered as part of driveway for purposes of determining overall width, size and area of driveway.
- A paved parking pad not to exceed 12' x 24' may be constructed adjacent to a garage on a lot provided that it complies with all other requirements of this section.
- No driveway located in a front yard of any lot shall extend more than 12' across the front elevation of the residence located on such lot except when the driveway connects to an attached garage.
- **Pre pour inspection required. Call 24 hours in advance to schedule. 708-343-8700.**

ENTRADAS – ACERAS DE LA PLATAFORMA DE ESTACIONAMIENTO – PATIOS

Envíe una aplicación de construcción completada junto con 2 conjuntos de planes y un plato de estudio que muestra la ubicación de la entrada, el cojín de estacionamiento, el patio o las aceras al Departamento de Construcción.

- Al enviar el permiso localizar la mejora en su plat de encuesta incluyen dimensiones.
- Las entradas de hormigón deben ser un mínimo de 4" de piedra triturada y 5" de hormigón.
- Las pavimentadoras de ladrillo deben ser un mínimo de 4" – 6" de base de piedra triturada, 1" de arena gruesa, 2 3/8" de pavimentación mínima.
- El asfalto debe ser un mínimo de 6" de piedra triturada y 2 1/2" – 3" de asfalto superficial.
- Ninguna entrada excederá los 24 pies de ancho, excepto que la anchura de una entrada puede exceder de 24 pies en el punto en que la entrada se conecta a un garaje y desde la conexión al garaje para una distancia que no exceda de 30' hacia la línea de lote principal.
- Ninguna entrada tendrá más de un corte de bordillo.
- Las entradas circulares están prohibidas.
- Ningún lote tendrá más de una entrada.
- Lotes entre 5.000 y 6000 sf, no más del 65% pueden estar cubiertos por superficies impermeables.
Lotes entre 6.001-8.000 sf, no más del 55%
Lotes 8.001 sf & over, no más del 50%
- Abutting paved o gravel sidewalks or patios considerados como parte de la entrada para determinar la anchura total, el tamaño y el área de entrada.
- Se puede construir una plataforma de aparcamiento pavimentada que no exceda de 12' x 24' adyacente a un garaje en un lote siempre que cumpla con todos los demás requisitos de esta sección.
- Ninguna entrada ubicada en un patio delantero de cualquier lote se extenderá más de 12' a través de la elevación frontal de la residencia ubicada en dicho lote, excepto cuando la entrada se conecta a un garaje adjunto.
- Al enviar el permiso localizar la mejora en su plat de encuesta incluyen dimensiones.
- **Se requiere una inspección previa al vertido. Llame con 24 horas de anticipación para programar. 708-343-8700.**

DRIVEWAYS – PARKING PAD - SIDEWALKS – PATIOS

Submit a completed Building Application along with 2 sets of plans and a plat of survey showing the location of driveway, parking pad, patio or sidewalks to the Building Department.

- When submitting permit locate improvement on your plat of survey include dimensions.
- Concrete driveways must be a minimum of 4" of crushed stone and 5" of concrete.
- Brick pavers must be a minimum of 4" – 6" of crushed stone base, 1" coarse sand, 2 3/8" minimum paver.
- Asphalt must be a minimum of 6" of crushed stone and 2 1/2" – 3" of surface asphalt.
- No driveway shall exceed 24 feet in width except that the width of a driveway may exceed 24 feet at the point that the driveway connects to a garage and from the connection to the garage for a distance not to exceed 30' toward the front lot line.
- No driveway shall have more than one curb cut.
- Circular driveways are prohibited.
- No lot shall have more than one driveway.
- Lots between 5,000 – 6000 sf, no more than 65% may be covered by impervious surfaces.
Lots between 6,001-8,000 sf, no more than 55%
Lots 8,001 sf & over, no more than 50%
- Abutting paved or gravel sidewalks or patios considered as part of driveway for purposes of determining overall width, size and area of driveway.
- A paved parking pad not to exceed 12' x 24' may be constructed adjacent to a garage on a lot provided that it complies with all other requirements of this section.
- No driveway located in a front yard of any lot shall extend more than 12' across the front elevation of the residence located on such lot except when the driveway connects to an attached garage.
- **Pre pour inspection required. Call 24 hours in advance to schedule. 708-343-8700.**

ENTRADAS – ACERAS DE LA PLATAFORMA DE ESTACIONAMIENTO – PATIOS

Envíe una aplicación de construcción completada junto con 2 conjuntos de planes y un plato de estudio que muestra la ubicación de la entrada, el cojín de estacionamiento, el patio o las aceras al Departamento de Construcción.

- Al enviar el permiso localizar la mejora en su plat de encuesta incluyen dimensiones.
- Las entradas de hormigón deben ser un mínimo de 4" de piedra triturada y 5" de hormigón.
- Las pavimentadoras de ladrillo deben ser un mínimo de 4" – 6" de base de piedra triturada, 1" de arena gruesa, 2 3/8" de pavimentación mínima.
- El asfalto debe ser un mínimo de 6" de piedra triturada y 2 1/2" – 3" de asfalto superficial.
- Ninguna entrada excederá los 24 pies de ancho, excepto que la anchura de una entrada puede exceder de 24 pies en el punto en que la entrada se conecta a un garaje y desde la conexión al garaje para una distancia que no exceda de 30' hacia la línea de lote principal.
- Ninguna entrada tendrá más de un corte de bordillo.
- Las entradas circulares están prohibidas.
- Ningún lote tendrá más de una entrada.
- Lotes entre 5.000 y 6000 sf, no más del 65% pueden estar cubiertos por superficies impermeables.
Lotes entre 6.001-8.000 sf, no más del 55%
Lotes 8.001 sf & over, no más del 50%
- Abutting paved o gravel sidewalks or patios considerados como parte de la entrada para determinar la anchura total, el tamaño y el área de entrada.
- Se puede construir una plataforma de aparcamiento pavimentada que no exceda de 12' x 24' adyacente a un garaje en un lote siempre que cumpla con todos los demás requisitos de esta sección.
- Ninguna entrada ubicada en un patio delantero de cualquier lote se extenderá más de 12' a través de la elevación frontal de la residencia ubicada en dicho lote, excepto cuando la entrada se conecta a un garaje adjunto.
- Al enviar el permiso localizar la mejora en su plat de encuesta incluyen dimensiones.
- **Se requiere una inspección previa al vertido. Llame con 24 horas de anticipación para programar. 708-343-8700.**

DRIVEWAYS – PARKING PAD - SIDEWALKS – PATIOS

Submit a completed Building Application along with 2 sets of plans and a plat of survey showing the location of driveway, parking pad, patio or sidewalks to the Building Department.

- When submitting permit locate improvement on your plat of survey include dimensions.
- Concrete driveways must be a minimum of 4" of crushed stone and 5" of concrete.
- Brick pavers must be a minimum of 4" – 6" of crushed stone base, 1" coarse sand, 2 3/8" minimum paver.
- Asphalt must be a minimum of 6" of crushed stone and 2 1/2" – 3" of surface asphalt.
- No driveway shall exceed 24 feet in width except that the width of a driveway may exceed 24 feet at the point that the driveway connects to a garage and from the connection to the garage for a distance not to exceed 30' toward the front lot line.
- No driveway shall have more than one curb cut.
- Circular driveways are prohibited.
- No lot shall have more than one driveway.
- Lots between 5,000 – 6000 sf, no more than 65% may be covered by impervious surfaces.
Lots between 6,001-8,000 sf, no more than 55%
Lots 8,001 sf & over, no more than 50%
- Abutting paved or gravel sidewalks or patios considered as part of driveway for purposes of determining overall width, size and area of driveway.
- A paved parking pad not to exceed 12' x 24' may be constructed adjacent to a garage on a lot provided that it complies with all other requirements of this section.
- No driveway located in a front yard of any lot shall extend more than 12' across the front elevation of the residence located on such lot except when the driveway connects to an attached garage.
- **Pre pour inspection required. Call 24 hours in advance to schedule. 708-343-8700.**

ENTRADAS – ACERAS DE LA PLATAFORMA DE ESTACIONAMIENTO – PATIOS

Envíe una aplicación de construcción completada junto con 2 conjuntos de planes y un plato de estudio que muestra la ubicación de la entrada, el cojín de estacionamiento, el patio o las aceras al Departamento de Construcción.

- Al enviar el permiso localizar la mejora en su plat de encuesta incluyen dimensiones.
- Las entradas de hormigón deben ser un mínimo de 4" de piedra triturada y 5" de hormigón.
- Las pavimentadoras de ladrillo deben ser un mínimo de 4" – 6" de base de piedra triturada, 1" de arena gruesa, 2 3/8" de pavimentación mínima.
- El asfalto debe ser un mínimo de 6" de piedra triturada y 2 1/2" – 3" de asfalto superficial.
- Ninguna entrada excederá los 24 pies de ancho, excepto que la anchura de una entrada puede exceder de 24 pies en el punto en que la entrada se conecta a un garaje y desde la conexión al garaje para una distancia que no exceda de 30' hacia la línea de lote principal.
- Ninguna entrada tendrá más de un corte de bordillo.
- Las entradas circulares están prohibidas.
- Ningún lote tendrá más de una entrada.
- Lotes entre 5.000 y 6000 sf, no más del 65% pueden estar cubiertos por superficies impermeables.
Lotes entre 6.001-8.000 sf, no más del 55%
Lotes 8.001 sf & over, no más del 50%
- Abutting paved o gravel sidewalks or patios considerados como parte de la entrada para determinar la anchura total, el tamaño y el área de entrada.
- Se puede construir una plataforma de aparcamiento pavimentada que no exceda de 12' x 24' adyacente a un garaje en un lote siempre que cumpla con todos los demás requisitos de esta sección.
- Ninguna entrada ubicada en un patio delantero de cualquier lote se extenderá más de 12' a través de la elevación frontal de la residencia ubicada en dicho lote, excepto cuando la entrada se conecta a un garaje adjunto.
- Al enviar el permiso localizar la mejora en su plat de encuesta incluyen dimensiones.
- **Se requiere una inspección previa al vertido. Llame con 24 horas de anticipación para programar. 708-343-8700.**

DRIVEWAYS – PARKING PAD - SIDEWALKS – PATIOS

Submit a completed Building Application along with 2 sets of plans and a plat of survey showing the location of driveway, parking pad, patio or sidewalks to the Building Department.

- When submitting permit locate improvement on your plat of survey include dimensions.
- Concrete driveways must be a minimum of 4" of crushed stone and 5" of concrete.
- Brick pavers must be a minimum of 4" – 6" of crushed stone base, 1" coarse sand, 2 3/8" minimum paver.
- Asphalt must be a minimum of 6" of crushed stone and 2 1/2" – 3" of surface asphalt.
- No driveway shall exceed 24 feet in width except that the width of a driveway may exceed 24 feet at the point that the driveway connects to a garage and from the connection to the garage for a distance not to exceed 30' toward the front lot line.
- No driveway shall have more than one curb cut.
- Circular driveways are prohibited.
- No lot shall have more than one driveway.
- Lots between 5,000 – 6000 sf, no more than 65% may be covered by impervious surfaces.
Lots between 6,001-8,000 sf, no more than 55%
Lots 8,001 sf & over, no more than 50%
- Abutting paved or gravel sidewalks or patios considered as part of driveway for purposes of determining overall width, size and area of driveway.
- A paved parking pad not to exceed 12' x 24' may be constructed adjacent to a garage on a lot provided that it complies with all other requirements of this section.
- No driveway located in a front yard of any lot shall extend more than 12' across the front elevation of the residence located on such lot except when the driveway connects to an attached garage.
- **Pre pour inspection required. Call 24 hours in advance to schedule. 708-343-8700.**

ENTRADAS – ACERAS DE LA PLATAFORMA DE ESTACIONAMIENTO – PATIOS

Envíe una aplicación de construcción completada junto con 2 conjuntos de planes y un plato de estudio que muestra la ubicación de la entrada, el cojín de estacionamiento, el patio o las aceras al Departamento de Construcción.

- Al enviar el permiso localizar la mejora en su plat de encuesta incluyen dimensiones.
- Las entradas de hormigón deben ser un mínimo de 4" de piedra triturada y 5" de hormigón.
- Las pavimentadoras de ladrillo deben ser un mínimo de 4" – 6" de base de piedra triturada, 1" de arena gruesa, 2 3/8" de pavimentación mínima.
- El asfalto debe ser un mínimo de 6" de piedra triturada y 2 1/2" – 3" de asfalto superficial.
- Ninguna entrada excederá los 24 pies de ancho, excepto que la anchura de una entrada puede exceder de 24 pies en el punto en que la entrada se conecta a un garaje y desde la conexión al garaje para una distancia que no exceda de 30' hacia la línea de lote principal.
- Ninguna entrada tendrá más de un corte de bordillo.
- Las entradas circulares están prohibidas.
- Ningún lote tendrá más de una entrada.
- Lotes entre 5.000 y 6000 sf, no más del 65% pueden estar cubiertos por superficies impermeables.
Lotes entre 6.001-8.000 sf, no más del 55%
Lotes 8.001 sf & over, no más del 50%
- Abutting paved o gravel sidewalks or patios considerados como parte de la entrada para determinar la anchura total, el tamaño y el área de entrada.
- Se puede construir una plataforma de aparcamiento pavimentada que no exceda de 12' x 24' adyacente a un garaje en un lote siempre que cumpla con todos los demás requisitos de esta sección.
- Ninguna entrada ubicada en un patio delantero de cualquier lote se extenderá más de 12' a través de la elevación frontal de la residencia ubicada en dicho lote, excepto cuando la entrada se conecta a un garaje adjunto.
- Al enviar el permiso localizar la mejora en su plat de encuesta incluyen dimensiones.
- **Se requiere una inspección previa al vertido. Llame con 24 horas de anticipación para programar. 708-343-8700.**

DRIVEWAYS – PARKING PAD - SIDEWALKS – PATIOS

Submit a completed Building Application along with 2 sets of plans and a plat of survey showing the location of driveway, parking pad, patio or sidewalks to the Building Department.

- When submitting permit locate improvement on your plat of survey include dimensions.
- Concrete driveways must be a minimum of 4" of crushed stone and 5" of concrete.
- Brick pavers must be a minimum of 4" – 6" of crushed stone base, 1" coarse sand, 2 3/8" minimum paver.
- Asphalt must be a minimum of 6" of crushed stone and 2 1/2" – 3" of surface asphalt.
- No driveway shall exceed 24 feet in width except that the width of a driveway may exceed 24 feet at the point that the driveway connects to a garage and from the connection to the garage for a distance not to exceed 30' toward the front lot line.
- No driveway shall have more than one curb cut.
- Circular driveways are prohibited.
- No lot shall have more than one driveway.
- Lots between 5,000 – 6000 sf, no more than 65% may be covered by impervious surfaces.
Lots between 6,001-8,000 sf, no more than 55%
Lots 8,001 sf & over, no more than 50%
- Abutting paved or gravel sidewalks or patios considered as part of driveway for purposes of determining overall width, size and area of driveway.
- A paved parking pad not to exceed 12' x 24' may be constructed adjacent to a garage on a lot provided that it complies with all other requirements of this section.
- No driveway located in a front yard of any lot shall extend more than 12' across the front elevation of the residence located on such lot except when the driveway connects to an attached garage.
- **Pre pour inspection required. Call 24 hours in advance to schedule. 708-343-8700.**

ENTRADAS – ACERAS DE LA PLATAFORMA DE ESTACIONAMIENTO – PATIOS

Envíe una aplicación de construcción completada junto con 2 conjuntos de planes y un plato de estudio que muestra la ubicación de la entrada, el cojín de estacionamiento, el patio o las aceras al Departamento de Construcción.

- Al enviar el permiso localizar la mejora en su plat de encuesta incluyen dimensiones.
- Las entradas de hormigón deben ser un mínimo de 4" de piedra triturada y 5" de hormigón.
- Las pavimentadoras de ladrillo deben ser un mínimo de 4" – 6" de base de piedra triturada, 1" de arena gruesa, 2 3/8" de pavimentación mínima.
- El asfalto debe ser un mínimo de 6" de piedra triturada y 2 1/2" – 3" de asfalto superficial.
- Ninguna entrada excederá los 24 pies de ancho, excepto que la anchura de una entrada puede exceder de 24 pies en el punto en que la entrada se conecta a un garaje y desde la conexión al garaje para una distancia que no exceda de 30' hacia la línea de lote principal.
- Ninguna entrada tendrá más de un corte de bordillo.
- Las entradas circulares están prohibidas.
- Ningún lote tendrá más de una entrada.
- Lotes entre 5.000 y 6000 sf, no más del 65% pueden estar cubiertos por superficies impermeables.
Lotes entre 6.001-8.000 sf, no más del 55%
Lotes 8.001 sf & over, no más del 50%
- Abutting paved o gravel sidewalks or patios considerados como parte de la entrada para determinar la anchura total, el tamaño y el área de entrada.
- Se puede construir una plataforma de aparcamiento pavimentada que no exceda de 12' x 24' adyacente a un garaje en un lote siempre que cumpla con todos los demás requisitos de esta sección.
- Ninguna entrada ubicada en un patio delantero de cualquier lote se extenderá más de 12' a través de la elevación frontal de la residencia ubicada en dicho lote, excepto cuando la entrada se conecta a un garaje adjunto.
- Al enviar el permiso localizar la mejora en su plat de encuesta incluyen dimensiones.
- **Se requiere una inspección previa al vertido. Llame con 24 horas de anticipación para programar. 708-343-8700.**

DRIVEWAYS – PARKING PAD - SIDEWALKS – PATIOS

Submit a completed Building Application along with 2 sets of plans and a plat of survey showing the location of driveway, parking pad, patio or sidewalks to the Building Department.

- When submitting permit locate improvement on your plat of survey include dimensions.
- Concrete driveways must be a minimum of 4" of crushed stone and 5" of concrete.
- Brick pavers must be a minimum of 4" – 6" of crushed stone base, 1" coarse sand, 2 3/8" minimum paver.
- Asphalt must be a minimum of 6" of crushed stone and 2 1/2" – 3" of surface asphalt.
- No driveway shall exceed 24 feet in width except that the width of a driveway may exceed 24 feet at the point that the driveway connects to a garage and from the connection to the garage for a distance not to exceed 30' toward the front lot line.
- No driveway shall have more than one curb cut.
- Circular driveways are prohibited.
- No lot shall have more than one driveway.
- Lots between 5,000 – 6000 sf, no more than 65% may be covered by impervious surfaces.
Lots between 6,001-8,000 sf, no more than 55%
Lots 8,001 sf & over, no more than 50%
- Abutting paved or gravel sidewalks or patios considered as part of driveway for purposes of determining overall width, size and area of driveway.
- A paved parking pad not to exceed 12' x 24' may be constructed adjacent to a garage on a lot provided that it complies with all other requirements of this section.
- No driveway located in a front yard of any lot shall extend more than 12' across the front elevation of the residence located on such lot except when the driveway connects to an attached garage.
- **Pre pour inspection required. Call 24 hours in advance to schedule. 708-343-8700.**

ENTRADAS – ACERAS DE LA PLATAFORMA DE ESTACIONAMIENTO – PATIOS

Envíe una aplicación de construcción completada junto con 2 conjuntos de planes y un plato de estudio que muestra la ubicación de la entrada, el cojín de estacionamiento, el patio o las aceras al Departamento de Construcción.

- Al enviar el permiso localizar la mejora en su plat de encuesta incluyen dimensiones.
- Las entradas de hormigón deben ser un mínimo de 4" de piedra triturada y 5" de hormigón.
- Las pavimentadoras de ladrillo deben ser un mínimo de 4" – 6" de base de piedra triturada, 1" de arena gruesa, 2 3/8" de pavimentación mínima.
- El asfalto debe ser un mínimo de 6" de piedra triturada y 2 1/2" – 3" de asfalto superficial.
- Ninguna entrada excederá los 24 pies de ancho, excepto que la anchura de una entrada puede exceder de 24 pies en el punto en que la entrada se conecta a un garaje y desde la conexión al garaje para una distancia que no exceda de 30' hacia la línea de lote principal.
- Ninguna entrada tendrá más de un corte de bordillo.
- Las entradas circulares están prohibidas.
- Ningún lote tendrá más de una entrada.
- Lotes entre 5.000 y 6000 sf, no más del 65% pueden estar cubiertos por superficies impermeables.
Lotes entre 6.001-8.000 sf, no más del 55%
Lotes 8.001 sf & over, no más del 50%
- Abutting paved o gravel sidewalks or patios considerados como parte de la entrada para determinar la anchura total, el tamaño y el área de entrada.
- Se puede construir una plataforma de aparcamiento pavimentada que no exceda de 12' x 24' adyacente a un garaje en un lote siempre que cumpla con todos los demás requisitos de esta sección.
- Ninguna entrada ubicada en un patio delantero de cualquier lote se extenderá más de 12' a través de la elevación frontal de la residencia ubicada en dicho lote, excepto cuando la entrada se conecta a un garaje adjunto.
- Al enviar el permiso localizar la mejora en su plat de encuesta incluyen dimensiones.
- **Se requiere una inspección previa al vertido. Llame con 24 horas de anticipación para programar. 708-343-8700.**

DRIVEWAYS – PARKING PAD - SIDEWALKS – PATIOS

Submit a completed Building Application along with 2 sets of plans and a plat of survey showing the location of driveway, parking pad, patio or sidewalks to the Building Department.

- When submitting permit locate improvement on your plat of survey include dimensions.
- Concrete driveways must be a minimum of 4" of crushed stone and 5" of concrete.
- Brick pavers must be a minimum of 4" – 6" of crushed stone base, 1" coarse sand, 2 3/8" minimum paver.
- Asphalt must be a minimum of 6" of crushed stone and 2 1/2" – 3" of surface asphalt.
- No driveway shall exceed 24 feet in width except that the width of a driveway may exceed 24 feet at the point that the driveway connects to a garage and from the connection to the garage for a distance not to exceed 30' toward the front lot line.
- No driveway shall have more than one curb cut.
- Circular driveways are prohibited.
- No lot shall have more than one driveway.
- Lots between 5,000 – 6000 sf, no more than 65% may be covered by impervious surfaces.
Lots between 6,001-8,000 sf, no more than 55%
Lots 8,001 sf & over, no more than 50%
- Abutting paved or gravel sidewalks or patios considered as part of driveway for purposes of determining overall width, size and area of driveway.
- A paved parking pad not to exceed 12' x 24' may be constructed adjacent to a garage on a lot provided that it complies with all other requirements of this section.
- No driveway located in a front yard of any lot shall extend more than 12' across the front elevation of the residence located on such lot except when the driveway connects to an attached garage.
- **Pre pour inspection required. Call 24 hours in advance to schedule. 708-343-8700.**

ENTRADAS – ACERAS DE LA PLATAFORMA DE ESTACIONAMIENTO – PATIOS

Envíe una aplicación de construcción completada junto con 2 conjuntos de planes y un plato de estudio que muestra la ubicación de la entrada, el cojín de estacionamiento, el patio o las aceras al Departamento de Construcción.

- Al enviar el permiso localizar la mejora en su plat de encuesta incluyen dimensiones.
- Las entradas de hormigón deben ser un mínimo de 4" de piedra triturada y 5" de hormigón.
- Las pavimentadoras de ladrillo deben ser un mínimo de 4" – 6" de base de piedra triturada, 1" de arena gruesa, 2 3/8" de pavimentación mínima.
- El asfalto debe ser un mínimo de 6" de piedra triturada y 2 1/2" – 3" de asfalto superficial.
- Ninguna entrada excederá los 24 pies de ancho, excepto que la anchura de una entrada puede exceder de 24 pies en el punto en que la entrada se conecta a un garaje y desde la conexión al garaje para una distancia que no exceda de 30' hacia la línea de lote principal.
- Ninguna entrada tendrá más de un corte de bordillo.
- Las entradas circulares están prohibidas.
- Ningún lote tendrá más de una entrada.
- Lotes entre 5.000 y 6000 sf, no más del 65% pueden estar cubiertos por superficies impermeables.
Lotes entre 6.001-8.000 sf, no más del 55%
Lotes 8.001 sf & over, no más del 50%
- Abutting paved o gravel sidewalks or patios considerados como parte de la entrada para determinar la anchura total, el tamaño y el área de entrada.
- Se puede construir una plataforma de aparcamiento pavimentada que no exceda de 12' x 24' adyacente a un garaje en un lote siempre que cumpla con todos los demás requisitos de esta sección.
- Ninguna entrada ubicada en un patio delantero de cualquier lote se extenderá más de 12' a través de la elevación frontal de la residencia ubicada en dicho lote, excepto cuando la entrada se conecta a un garaje adjunto.
- Al enviar el permiso localizar la mejora en su plat de encuesta incluyen dimensiones.
- **Se requiere una inspección previa al vertido. Llame con 24 horas de anticipación para programar. 708-343-8700.**

DRIVEWAYS – PARKING PAD - SIDEWALKS – PATIOS

Submit a completed Building Application along with 2 sets of plans and a plat of survey showing the location of driveway, parking pad, patio or sidewalks to the Building Department.

- When submitting permit locate improvement on your plat of survey include dimensions.
- Concrete driveways must be a minimum of 4" of crushed stone and 5" of concrete.
- Brick pavers must be a minimum of 4" – 6" of crushed stone base, 1" coarse sand, 2 3/8" minimum paver.
- Asphalt must be a minimum of 6" of crushed stone and 2 1/2" – 3" of surface asphalt.
- No driveway shall exceed 24 feet in width except that the width of a driveway may exceed 24 feet at the point that the driveway connects to a garage and from the connection to the garage for a distance not to exceed 30' toward the front lot line.
- No driveway shall have more than one curb cut.
- Circular driveways are prohibited.
- No lot shall have more than one driveway.
- Lots between 5,000 – 6000 sf, no more than 65% may be covered by impervious surfaces.
Lots between 6,001-8,000 sf, no more than 55%
Lots 8,001 sf & over, no more than 50%
- Abutting paved or gravel sidewalks or patios considered as part of driveway for purposes of determining overall width, size and area of driveway.
- A paved parking pad not to exceed 12' x 24' may be constructed adjacent to a garage on a lot provided that it complies with all other requirements of this section.
- No driveway located in a front yard of any lot shall extend more than 12' across the front elevation of the residence located on such lot except when the driveway connects to an attached garage.
- **Pre pour inspection required. Call 24 hours in advance to schedule. 708-343-8700.**

ENTRADAS – ACERAS DE LA PLATAFORMA DE ESTACIONAMIENTO – PATIOS

Envíe una aplicación de construcción completada junto con 2 conjuntos de planes y un plato de estudio que muestra la ubicación de la entrada, el cojín de estacionamiento, el patio o las aceras al Departamento de Construcción.

- Al enviar el permiso localizar la mejora en su plat de encuesta incluyen dimensiones.
- Las entradas de hormigón deben ser un mínimo de 4" de piedra triturada y 5" de hormigón.
- Las pavimentadoras de ladrillo deben ser un mínimo de 4" – 6" de base de piedra triturada, 1" de arena gruesa, 2 3/8" de pavimentación mínima.
- El asfalto debe ser un mínimo de 6" de piedra triturada y 2 1/2" – 3" de asfalto superficial.
- Ninguna entrada excederá los 24 pies de ancho, excepto que la anchura de una entrada puede exceder de 24 pies en el punto en que la entrada se conecta a un garaje y desde la conexión al garaje para una distancia que no exceda de 30' hacia la línea de lote principal.
- Ninguna entrada tendrá más de un corte de bordillo.
- Las entradas circulares están prohibidas.
- Ningún lote tendrá más de una entrada.
- Lotes entre 5.000 y 6000 sf, no más del 65% pueden estar cubiertos por superficies impermeables.
Lotes entre 6.001-8.000 sf, no más del 55%
Lotes 8.001 sf & over, no más del 50%
- Abutting paved o gravel sidewalks or patios considerados como parte de la entrada para determinar la anchura total, el tamaño y el área de entrada.
- Se puede construir una plataforma de aparcamiento pavimentada que no exceda de 12' x 24' adyacente a un garaje en un lote siempre que cumpla con todos los demás requisitos de esta sección.
- Ninguna entrada ubicada en un patio delantero de cualquier lote se extenderá más de 12' a través de la elevación frontal de la residencia ubicada en dicho lote, excepto cuando la entrada se conecta a un garaje adjunto.
- Al enviar el permiso localizar la mejora en su plat de encuesta incluyen dimensiones.
- **Se requiere una inspección previa al vertido. Llame con 24 horas de anticipación para programar. 708-343-8700.**

DRIVEWAYS – PARKING PAD - SIDEWALKS – PATIOS

Submit a completed Building Application along with 2 sets of plans and a plat of survey showing the location of driveway, parking pad, patio or sidewalks to the Building Department.

- When submitting permit locate improvement on your plat of survey include dimensions.
- Concrete driveways must be a minimum of 4" of crushed stone and 5" of concrete.
- Brick pavers must be a minimum of 4" – 6" of crushed stone base, 1" coarse sand, 2 3/8" minimum paver.
- Asphalt must be a minimum of 6" of crushed stone and 2 1/2" – 3" of surface asphalt.
- No driveway shall exceed 24 feet in width except that the width of a driveway may exceed 24 feet at the point that the driveway connects to a garage and from the connection to the garage for a distance not to exceed 30' toward the front lot line.
- No driveway shall have more than one curb cut.
- Circular driveways are prohibited.
- No lot shall have more than one driveway.
- Lots between 5,000 – 6000 sf, no more than 65% may be covered by impervious surfaces.
Lots between 6,001-8,000 sf, no more than 55%
Lots 8,001 sf & over, no more than 50%
- Abutting paved or gravel sidewalks or patios considered as part of driveway for purposes of determining overall width, size and area of driveway.
- A paved parking pad not to exceed 12' x 24' may be constructed adjacent to a garage on a lot provided that it complies with all other requirements of this section.
- No driveway located in a front yard of any lot shall extend more than 12' across the front elevation of the residence located on such lot except when the driveway connects to an attached garage.
- **Pre pour inspection required. Call 24 hours in advance to schedule. 708-343-8700.**

ENTRADAS – ACERAS DE LA PLATAFORMA DE ESTACIONAMIENTO – PATIOS

Envíe una aplicación de construcción completada junto con 2 conjuntos de planes y un plato de estudio que muestra la ubicación de la entrada, el cojín de estacionamiento, el patio o las aceras al Departamento de Construcción.

- Al enviar el permiso localizar la mejora en su plat de encuesta incluyen dimensiones.
- Las entradas de hormigón deben ser un mínimo de 4" de piedra triturada y 5" de hormigón.
- Las pavimentadoras de ladrillo deben ser un mínimo de 4" – 6" de base de piedra triturada, 1" de arena gruesa, 2 3/8" de pavimentación mínima.
- El asfalto debe ser un mínimo de 6" de piedra triturada y 2 1/2" – 3" de asfalto superficial.
- Ninguna entrada excederá los 24 pies de ancho, excepto que la anchura de una entrada puede exceder de 24 pies en el punto en que la entrada se conecta a un garaje y desde la conexión al garaje para una distancia que no exceda de 30' hacia la línea de lote principal.
- Ninguna entrada tendrá más de un corte de bordillo.
- Las entradas circulares están prohibidas.
- Ningún lote tendrá más de una entrada.
- Lotes entre 5.000 y 6000 sf, no más del 65% pueden estar cubiertos por superficies impermeables.
Lotes entre 6.001-8.000 sf, no más del 55%
Lotes 8.001 sf & over, no más del 50%
- Abutting paved o gravel sidewalks or patios considerados como parte de la entrada para determinar la anchura total, el tamaño y el área de entrada.
- Se puede construir una plataforma de aparcamiento pavimentada que no exceda de 12' x 24' adyacente a un garaje en un lote siempre que cumpla con todos los demás requisitos de esta sección.
- Ninguna entrada ubicada en un patio delantero de cualquier lote se extenderá más de 12' a través de la elevación frontal de la residencia ubicada en dicho lote, excepto cuando la entrada se conecta a un garaje adjunto.
- Al enviar el permiso localizar la mejora en su plat de encuesta incluyen dimensiones.
- **Se requiere una inspección previa al vertido. Llame con 24 horas de anticipación para programar. 708-343-8700.**

DRIVEWAYS – PARKING PAD - SIDEWALKS – PATIOS

Submit a completed Building Application along with 2 sets of plans and a plat of survey showing the location of driveway, parking pad, patio or sidewalks to the Building Department.

- When submitting permit locate improvement on your plat of survey include dimensions.
- Concrete driveways must be a minimum of 4" of crushed stone and 5" of concrete.
- Brick pavers must be a minimum of 4" – 6" of crushed stone base, 1" coarse sand, 2 3/8" minimum paver.
- Asphalt must be a minimum of 6" of crushed stone and 2 1/2" – 3" of surface asphalt.
- No driveway shall exceed 24 feet in width except that the width of a driveway may exceed 24 feet at the point that the driveway connects to a garage and from the connection to the garage for a distance not to exceed 30' toward the front lot line.
- No driveway shall have more than one curb cut.
- Circular driveways are prohibited.
- No lot shall have more than one driveway.
- Lots between 5,000 – 6000 sf, no more than 65% may be covered by impervious surfaces.
Lots between 6,001-8,000 sf, no more than 55%
Lots 8,001 sf & over, no more than 50%
- Abutting paved or gravel sidewalks or patios considered as part of driveway for purposes of determining overall width, size and area of driveway.
- A paved parking pad not to exceed 12' x 24' may be constructed adjacent to a garage on a lot provided that it complies with all other requirements of this section.
- No driveway located in a front yard of any lot shall extend more than 12' across the front elevation of the residence located on such lot except when the driveway connects to an attached garage.
- **Pre pour inspection required. Call 24 hours in advance to schedule. 708-343-8700.**

ENTRADAS – ACERAS DE LA PLATAFORMA DE ESTACIONAMIENTO – PATIOS

Envíe una aplicación de construcción completada junto con 2 conjuntos de planes y un plato de estudio que muestra la ubicación de la entrada, el cojín de estacionamiento, el patio o las aceras al Departamento de Construcción.

- Al enviar el permiso localizar la mejora en su plat de encuesta incluyen dimensiones.
- Las entradas de hormigón deben ser un mínimo de 4" de piedra triturada y 5" de hormigón.
- Las pavimentadoras de ladrillo deben ser un mínimo de 4" – 6" de base de piedra triturada, 1" de arena gruesa, 2 3/8" de pavimentación mínima.
- El asfalto debe ser un mínimo de 6" de piedra triturada y 2 1/2" – 3" de asfalto superficial.
- Ninguna entrada excederá los 24 pies de ancho, excepto que la anchura de una entrada puede exceder de 24 pies en el punto en que la entrada se conecta a un garaje y desde la conexión al garaje para una distancia que no exceda de 30' hacia la línea de lote principal.
- Ninguna entrada tendrá más de un corte de bordillo.
- Las entradas circulares están prohibidas.
- Ningún lote tendrá más de una entrada.
- Lotes entre 5.000 y 6000 sf, no más del 65% pueden estar cubiertos por superficies impermeables.
Lotes entre 6.001-8.000 sf, no más del 55%
Lotes 8.001 sf & over, no más del 50%
- Abutting paved o gravel sidewalks or patios considerados como parte de la entrada para determinar la anchura total, el tamaño y el área de entrada.
- Se puede construir una plataforma de aparcamiento pavimentada que no exceda de 12' x 24' adyacente a un garaje en un lote siempre que cumpla con todos los demás requisitos de esta sección.
- Ninguna entrada ubicada en un patio delantero de cualquier lote se extenderá más de 12' a través de la elevación frontal de la residencia ubicada en dicho lote, excepto cuando la entrada se conecta a un garaje adjunto.
- Al enviar el permiso localizar la mejora en su plat de encuesta incluyen dimensiones.
- **Se requiere una inspección previa al vertido. Llame con 24 horas de anticipación para programar. 708-343-8700.**

DRIVEWAYS – PARKING PAD - SIDEWALKS – PATIOS

Submit a completed Building Application along with 2 sets of plans and a plat of survey showing the location of driveway, parking pad, patio or sidewalks to the Building Department.

- When submitting permit locate improvement on your plat of survey include dimensions.
- Concrete driveways must be a minimum of 4" of crushed stone and 5" of concrete.
- Brick pavers must be a minimum of 4" – 6" of crushed stone base, 1" coarse sand, 2 3/8" minimum paver.
- Asphalt must be a minimum of 6" of crushed stone and 2 1/2" – 3" of surface asphalt.
- No driveway shall exceed 24 feet in width except that the width of a driveway may exceed 24 feet at the point that the driveway connects to a garage and from the connection to the garage for a distance not to exceed 30' toward the front lot line.
- No driveway shall have more than one curb cut.
- Circular driveways are prohibited.
- No lot shall have more than one driveway.
- Lots between 5,000 – 6000 sf, no more than 65% may be covered by impervious surfaces.
Lots between 6,001-8,000 sf, no more than 55%
Lots 8,001 sf & over, no more than 50%
- Abutting paved or gravel sidewalks or patios considered as part of driveway for purposes of determining overall width, size and area of driveway.
- A paved parking pad not to exceed 12' x 24' may be constructed adjacent to a garage on a lot provided that it complies with all other requirements of this section.
- No driveway located in a front yard of any lot shall extend more than 12' across the front elevation of the residence located on such lot except when the driveway connects to an attached garage.
- **Pre pour inspection required. Call 24 hours in advance to schedule. 708-343-8700.**

ENTRADAS – ACERAS DE LA PLATAFORMA DE ESTACIONAMIENTO – PATIOS

Envíe una aplicación de construcción completada junto con 2 conjuntos de planes y un plato de estudio que muestra la ubicación de la entrada, el cojín de estacionamiento, el patio o las aceras al Departamento de Construcción.

- Al enviar el permiso localizar la mejora en su plat de encuesta incluyen dimensiones.
- Las entradas de hormigón deben ser un mínimo de 4" de piedra triturada y 5" de hormigón.
- Las pavimentadoras de ladrillo deben ser un mínimo de 4" – 6" de base de piedra triturada, 1" de arena gruesa, 2 3/8" de pavimentación mínima.
- El asfalto debe ser un mínimo de 6" de piedra triturada y 2 1/2" – 3" de asfalto superficial.
- Ninguna entrada excederá los 24 pies de ancho, excepto que la anchura de una entrada puede exceder de 24 pies en el punto en que la entrada se conecta a un garaje y desde la conexión al garaje para una distancia que no exceda de 30' hacia la línea de lote principal.
- Ninguna entrada tendrá más de un corte de bordillo.
- Las entradas circulares están prohibidas.
- Ningún lote tendrá más de una entrada.
- Lotes entre 5.000 y 6000 sf, no más del 65% pueden estar cubiertos por superficies impermeables.
Lotes entre 6.001-8.000 sf, no más del 55%
Lotes 8.001 sf & over, no más del 50%
- Abutting paved o gravel sidewalks or patios considerados como parte de la entrada para determinar la anchura total, el tamaño y el área de entrada.
- Se puede construir una plataforma de aparcamiento pavimentada que no exceda de 12' x 24' adyacente a un garaje en un lote siempre que cumpla con todos los demás requisitos de esta sección.
- Ninguna entrada ubicada en un patio delantero de cualquier lote se extenderá más de 12' a través de la elevación frontal de la residencia ubicada en dicho lote, excepto cuando la entrada se conecta a un garaje adjunto.
- Al enviar el permiso localizar la mejora en su plat de encuesta incluyen dimensiones.
- **Se requiere una inspección previa al vertido. Llame con 24 horas de anticipación para programar. 708-343-8700.**

DRIVEWAYS – PARKING PAD - SIDEWALKS – PATIOS

Submit a completed Building Application along with 2 sets of plans and a plat of survey showing the location of driveway, parking pad, patio or sidewalks to the Building Department.

- When submitting permit locate improvement on your plat of survey include dimensions.
- Concrete driveways must be a minimum of 4" of crushed stone and 5" of concrete.
- Brick pavers must be a minimum of 4" – 6" of crushed stone base, 1" coarse sand, 2 3/8" minimum paver.
- Asphalt must be a minimum of 6" of crushed stone and 2 1/2" – 3" of surface asphalt.
- No driveway shall exceed 24 feet in width except that the width of a driveway may exceed 24 feet at the point that the driveway connects to a garage and from the connection to the garage for a distance not to exceed 30' toward the front lot line.
- No driveway shall have more than one curb cut.
- Circular driveways are prohibited.
- No lot shall have more than one driveway.
- Lots between 5,000 – 6000 sf, no more than 65% may be covered by impervious surfaces.
Lots between 6,001-8,000 sf, no more than 55%
Lots 8,001 sf & over, no more than 50%
- Abutting paved or gravel sidewalks or patios considered as part of driveway for purposes of determining overall width, size and area of driveway.
- A paved parking pad not to exceed 12' x 24' may be constructed adjacent to a garage on a lot provided that it complies with all other requirements of this section.
- No driveway located in a front yard of any lot shall extend more than 12' across the front elevation of the residence located on such lot except when the driveway connects to an attached garage.
- **Pre pour inspection required. Call 24 hours in advance to schedule. 708-343-8700.**

ENTRADAS – ACERAS DE LA PLATAFORMA DE ESTACIONAMIENTO – PATIOS

Envíe una aplicación de construcción completada junto con 2 conjuntos de planes y un plato de estudio que muestra la ubicación de la entrada, el cojín de estacionamiento, el patio o las aceras al Departamento de Construcción.

- Al enviar el permiso localizar la mejora en su plat de encuesta incluyen dimensiones.
- Las entradas de hormigón deben ser un mínimo de 4" de piedra triturada y 5" de hormigón.
- Las pavimentadoras de ladrillo deben ser un mínimo de 4" – 6" de base de piedra triturada, 1" de arena gruesa, 2 3/8" de pavimentación mínima.
- El asfalto debe ser un mínimo de 6" de piedra triturada y 2 1/2" – 3" de asfalto superficial.
- Ninguna entrada excederá los 24 pies de ancho, excepto que la anchura de una entrada puede exceder de 24 pies en el punto en que la entrada se conecta a un garaje y desde la conexión al garaje para una distancia que no exceda de 30' hacia la línea de lote principal.
- Ninguna entrada tendrá más de un corte de bordillo.
- Las entradas circulares están prohibidas.
- Ningún lote tendrá más de una entrada.
- Lotes entre 5.000 y 6000 sf, no más del 65% pueden estar cubiertos por superficies impermeables.
Lotes entre 6.001-8.000 sf, no más del 55%
Lotes 8.001 sf & over, no más del 50%
- Abutting paved o gravel sidewalks or patios considerados como parte de la entrada para determinar la anchura total, el tamaño y el área de entrada.
- Se puede construir una plataforma de aparcamiento pavimentada que no exceda de 12' x 24' adyacente a un garaje en un lote siempre que cumpla con todos los demás requisitos de esta sección.
- Ninguna entrada ubicada en un patio delantero de cualquier lote se extenderá más de 12' a través de la elevación frontal de la residencia ubicada en dicho lote, excepto cuando la entrada se conecta a un garaje adjunto.
- Al enviar el permiso localizar la mejora en su plat de encuesta incluyen dimensiones.
- **Se requiere una inspección previa al vertido. Llame con 24 horas de anticipación para programar. 708-343-8700.**

DRIVEWAYS – PARKING PAD - SIDEWALKS – PATIOS

Submit a completed Building Application along with 2 sets of plans and a plat of survey showing the location of driveway, parking pad, patio or sidewalks to the Building Department.

- When submitting permit locate improvement on your plat of survey include dimensions.
- Concrete driveways must be a minimum of 4" of crushed stone and 5" of concrete.
- Brick pavers must be a minimum of 4" – 6" of crushed stone base, 1" coarse sand, 2 3/8" minimum paver.
- Asphalt must be a minimum of 6" of crushed stone and 2 1/2" – 3" of surface asphalt.
- No driveway shall exceed 24 feet in width except that the width of a driveway may exceed 24 feet at the point that the driveway connects to a garage and from the connection to the garage for a distance not to exceed 30' toward the front lot line.
- No driveway shall have more than one curb cut.
- Circular driveways are prohibited.
- No lot shall have more than one driveway.
- Lots between 5,000 – 6000 sf, no more than 65% may be covered by impervious surfaces.
Lots between 6,001-8,000 sf, no more than 55%
Lots 8,001 sf & over, no more than 50%
- Abutting paved or gravel sidewalks or patios considered as part of driveway for purposes of determining overall width, size and area of driveway.
- A paved parking pad not to exceed 12' x 24' may be constructed adjacent to a garage on a lot provided that it complies with all other requirements of this section.
- No driveway located in a front yard of any lot shall extend more than 12' across the front elevation of the residence located on such lot except when the driveway connects to an attached garage.
- **Pre pour inspection required. Call 24 hours in advance to schedule. 708-343-8700.**

ENTRADAS – ACERAS DE LA PLATAFORMA DE ESTACIONAMIENTO – PATIOS

Envíe una aplicación de construcción completada junto con 2 conjuntos de planes y un plato de estudio que muestra la ubicación de la entrada, el cojín de estacionamiento, el patio o las aceras al Departamento de Construcción.

- Al enviar el permiso localizar la mejora en su plat de encuesta incluyen dimensiones.
- Las entradas de hormigón deben ser un mínimo de 4" de piedra triturada y 5" de hormigón.
- Las pavimentadoras de ladrillo deben ser un mínimo de 4" – 6" de base de piedra triturada, 1" de arena gruesa, 2 3/8" de pavimentación mínima.
- El asfalto debe ser un mínimo de 6" de piedra triturada y 2 1/2" – 3" de asfalto superficial.
- Ninguna entrada excederá los 24 pies de ancho, excepto que la anchura de una entrada puede exceder de 24 pies en el punto en que la entrada se conecta a un garaje y desde la conexión al garaje para una distancia que no exceda de 30' hacia la línea de lote principal.
- Ninguna entrada tendrá más de un corte de bordillo.
- Las entradas circulares están prohibidas.
- Ningún lote tendrá más de una entrada.
- Lotes entre 5.000 y 6000 sf, no más del 65% pueden estar cubiertos por superficies impermeables.
Lotes entre 6.001-8.000 sf, no más del 55%
Lotes 8.001 sf & over, no más del 50%
- Abutting paved o gravel sidewalks or patios considerados como parte de la entrada para determinar la anchura total, el tamaño y el área de entrada.
- Se puede construir una plataforma de aparcamiento pavimentada que no exceda de 12' x 24' adyacente a un garaje en un lote siempre que cumpla con todos los demás requisitos de esta sección.
- Ninguna entrada ubicada en un patio delantero de cualquier lote se extenderá más de 12' a través de la elevación frontal de la residencia ubicada en dicho lote, excepto cuando la entrada se conecta a un garaje adjunto.
- Al enviar el permiso localizar la mejora en su plat de encuesta incluyen dimensiones.
- **Se requiere una inspección previa al vertido. Llame con 24 horas de anticipación para programar. 708-343-8700.**

DRIVEWAYS – PARKING PAD - SIDEWALKS – PATIOS

Submit a completed Building Application along with 2 sets of plans and a plat of survey showing the location of driveway, parking pad, patio or sidewalks to the Building Department.

- When submitting permit locate improvement on your plat of survey include dimensions.
- Concrete driveways must be a minimum of 4" of crushed stone and 5" of concrete.
- Brick pavers must be a minimum of 4" – 6" of crushed stone base, 1" coarse sand, 2 3/8" minimum paver.
- Asphalt must be a minimum of 6" of crushed stone and 2 1/2" – 3" of surface asphalt.
- No driveway shall exceed 24 feet in width except that the width of a driveway may exceed 24 feet at the point that the driveway connects to a garage and from the connection to the garage for a distance not to exceed 30' toward the front lot line.
- No driveway shall have more than one curb cut.
- Circular driveways are prohibited.
- No lot shall have more than one driveway.
- Lots between 5,000 – 6000 sf, no more than 65% may be covered by impervious surfaces.
Lots between 6,001-8,000 sf, no more than 55%
Lots 8,001 sf & over, no more than 50%
- Abutting paved or gravel sidewalks or patios considered as part of driveway for purposes of determining overall width, size and area of driveway.
- A paved parking pad not to exceed 12' x 24' may be constructed adjacent to a garage on a lot provided that it complies with all other requirements of this section.
- No driveway located in a front yard of any lot shall extend more than 12' across the front elevation of the residence located on such lot except when the driveway connects to an attached garage.
- **Pre pour inspection required. Call 24 hours in advance to schedule. 708-343-8700.**

ENTRADAS – ACERAS DE LA PLATAFORMA DE ESTACIONAMIENTO – PATIOS

Envíe una aplicación de construcción completada junto con 2 conjuntos de planes y un plato de estudio que muestra la ubicación de la entrada, el cojín de estacionamiento, el patio o las aceras al Departamento de Construcción.

- Al enviar el permiso localizar la mejora en su plat de encuesta incluyen dimensiones.
- Las entradas de hormigón deben ser un mínimo de 4" de piedra triturada y 5" de hormigón.
- Las pavimentadoras de ladrillo deben ser un mínimo de 4" – 6" de base de piedra triturada, 1" de arena gruesa, 2 3/8" de pavimentación mínima.
- El asfalto debe ser un mínimo de 6" de piedra triturada y 2 1/2" – 3" de asfalto superficial.
- Ninguna entrada excederá los 24 pies de ancho, excepto que la anchura de una entrada puede exceder de 24 pies en el punto en que la entrada se conecta a un garaje y desde la conexión al garaje para una distancia que no exceda de 30' hacia la línea de lote principal.
- Ninguna entrada tendrá más de un corte de bordillo.
- Las entradas circulares están prohibidas.
- Ningún lote tendrá más de una entrada.
- Lotes entre 5.000 y 6000 sf, no más del 65% pueden estar cubiertos por superficies impermeables.
Lotes entre 6.001-8.000 sf, no más del 55%
Lotes 8.001 sf & over, no más del 50%
- Abutting paved o gravel sidewalks or patios considerados como parte de la entrada para determinar la anchura total, el tamaño y el área de entrada.
- Se puede construir una plataforma de aparcamiento pavimentada que no exceda de 12' x 24' adyacente a un garaje en un lote siempre que cumpla con todos los demás requisitos de esta sección.
- Ninguna entrada ubicada en un patio delantero de cualquier lote se extenderá más de 12' a través de la elevación frontal de la residencia ubicada en dicho lote, excepto cuando la entrada se conecta a un garaje adjunto.
- Al enviar el permiso localizar la mejora en su plat de encuesta incluyen dimensiones.
- **Se requiere una inspección previa al vertido. Llame con 24 horas de anticipación para programar. 708-343-8700.**

DRIVEWAYS – PARKING PAD - SIDEWALKS – PATIOS

Submit a completed Building Application along with 2 sets of plans and a plat of survey showing the location of driveway, parking pad, patio or sidewalks to the Building Department.

- When submitting permit locate improvement on your plat of survey include dimensions.
- Concrete driveways must be a minimum of 4" of crushed stone and 5" of concrete.
- Brick pavers must be a minimum of 4" – 6" of crushed stone base, 1" coarse sand, 2 3/8" minimum paver.
- Asphalt must be a minimum of 6" of crushed stone and 2 1/2" – 3" of surface asphalt.
- No driveway shall exceed 24 feet in width except that the width of a driveway may exceed 24 feet at the point that the driveway connects to a garage and from the connection to the garage for a distance not to exceed 30' toward the front lot line.
- No driveway shall have more than one curb cut.
- Circular driveways are prohibited.
- No lot shall have more than one driveway.
- Lots between 5,000 – 6000 sf, no more than 65% may be covered by impervious surfaces.
Lots between 6,001-8,000 sf, no more than 55%
Lots 8,001 sf & over, no more than 50%
- Abutting paved or gravel sidewalks or patios considered as part of driveway for purposes of determining overall width, size and area of driveway.
- A paved parking pad not to exceed 12' x 24' may be constructed adjacent to a garage on a lot provided that it complies with all other requirements of this section.
- No driveway located in a front yard of any lot shall extend more than 12' across the front elevation of the residence located on such lot except when the driveway connects to an attached garage.
- **Pre pour inspection required. Call 24 hours in advance to schedule. 708-343-8700.**

ENTRADAS – ACERAS DE LA PLATAFORMA DE ESTACIONAMIENTO – PATIOS

Envíe una aplicación de construcción completada junto con 2 conjuntos de planes y un plato de estudio que muestra la ubicación de la entrada, el cojín de estacionamiento, el patio o las aceras al Departamento de Construcción.

- Al enviar el permiso localizar la mejora en su plat de encuesta incluyen dimensiones.
- Las entradas de hormigón deben ser un mínimo de 4" de piedra triturada y 5" de hormigón.
- Las pavimentadoras de ladrillo deben ser un mínimo de 4" – 6" de base de piedra triturada, 1" de arena gruesa, 2 3/8" de pavimentación mínima.
- El asfalto debe ser un mínimo de 6" de piedra triturada y 2 1/2" – 3" de asfalto superficial.
- Ninguna entrada excederá los 24 pies de ancho, excepto que la anchura de una entrada puede exceder de 24 pies en el punto en que la entrada se conecta a un garaje y desde la conexión al garaje para una distancia que no exceda de 30' hacia la línea de lote principal.
- Ninguna entrada tendrá más de un corte de bordillo.
- Las entradas circulares están prohibidas.
- Ningún lote tendrá más de una entrada.
- Lotes entre 5.000 y 6000 sf, no más del 65% pueden estar cubiertos por superficies impermeables.
Lotes entre 6.001-8.000 sf, no más del 55%
Lotes 8.001 sf & over, no más del 50%
- Abutting paved o gravel sidewalks or patios considerados como parte de la entrada para determinar la anchura total, el tamaño y el área de entrada.
- Se puede construir una plataforma de aparcamiento pavimentada que no exceda de 12' x 24' adyacente a un garaje en un lote siempre que cumpla con todos los demás requisitos de esta sección.
- Ninguna entrada ubicada en un patio delantero de cualquier lote se extenderá más de 12' a través de la elevación frontal de la residencia ubicada en dicho lote, excepto cuando la entrada se conecta a un garaje adjunto.
- Al enviar el permiso localizar la mejora en su plat de encuesta incluyen dimensiones.
- **Se requiere una inspección previa al vertido. Llame con 24 horas de anticipación para programar. 708-343-8700.**

DRIVEWAYS – PARKING PAD - SIDEWALKS – PATIOS

Submit a completed Building Application along with 2 sets of plans and a plat of survey showing the location of driveway, parking pad, patio or sidewalks to the Building Department.

- When submitting permit locate improvement on your plat of survey include dimensions.
- Concrete driveways must be a minimum of 4" of crushed stone and 5" of concrete.
- Brick pavers must be a minimum of 4" – 6" of crushed stone base, 1" coarse sand, 2 3/8" minimum paver.
- Asphalt must be a minimum of 6" of crushed stone and 2 1/2" – 3" of surface asphalt.
- No driveway shall exceed 24 feet in width except that the width of a driveway may exceed 24 feet at the point that the driveway connects to a garage and from the connection to the garage for a distance not to exceed 30' toward the front lot line.
- No driveway shall have more than one curb cut.
- Circular driveways are prohibited.
- No lot shall have more than one driveway.
- Lots between 5,000 – 6000 sf, no more than 65% may be covered by impervious surfaces.
Lots between 6,001-8,000 sf, no more than 55%
Lots 8,001 sf & over, no more than 50%
- Abutting paved or gravel sidewalks or patios considered as part of driveway for purposes of determining overall width, size and area of driveway.
- A paved parking pad not to exceed 12' x 24' may be constructed adjacent to a garage on a lot provided that it complies with all other requirements of this section.
- No driveway located in a front yard of any lot shall extend more than 12' across the front elevation of the residence located on such lot except when the driveway connects to an attached garage.
- **Pre pour inspection required. Call 24 hours in advance to schedule. 708-343-8700.**

ENTRADAS – ACERAS DE LA PLATAFORMA DE ESTACIONAMIENTO – PATIOS

Envíe una aplicación de construcción completada junto con 2 conjuntos de planes y un plato de estudio que muestra la ubicación de la entrada, el cojín de estacionamiento, el patio o las aceras al Departamento de Construcción.

- Al enviar el permiso localizar la mejora en su plat de encuesta incluyen dimensiones.
- Las entradas de hormigón deben ser un mínimo de 4" de piedra triturada y 5" de hormigón.
- Las pavimentadoras de ladrillo deben ser un mínimo de 4" – 6" de base de piedra triturada, 1" de arena gruesa, 2 3/8" de pavimentación mínima.
- El asfalto debe ser un mínimo de 6" de piedra triturada y 2 1/2" – 3" de asfalto superficial.
- Ninguna entrada excederá los 24 pies de ancho, excepto que la anchura de una entrada puede exceder de 24 pies en el punto en que la entrada se conecta a un garaje y desde la conexión al garaje para una distancia que no exceda de 30' hacia la línea de lote principal.
- Ninguna entrada tendrá más de un corte de bordillo.
- Las entradas circulares están prohibidas.
- Ningún lote tendrá más de una entrada.
- Lotes entre 5.000 y 6000 sf, no más del 65% pueden estar cubiertos por superficies impermeables.
Lotes entre 6.001-8.000 sf, no más del 55%
Lotes 8.001 sf & over, no más del 50%
- Abutting paved o gravel sidewalks or patios considerados como parte de la entrada para determinar la anchura total, el tamaño y el área de entrada.
- Se puede construir una plataforma de aparcamiento pavimentada que no exceda de 12' x 24' adyacente a un garaje en un lote siempre que cumpla con todos los demás requisitos de esta sección.
- Ninguna entrada ubicada en un patio delantero de cualquier lote se extenderá más de 12' a través de la elevación frontal de la residencia ubicada en dicho lote, excepto cuando la entrada se conecta a un garaje adjunto.
- Al enviar el permiso localizar la mejora en su plat de encuesta incluyen dimensiones.
- **Se requiere una inspección previa al vertido. Llame con 24 horas de anticipación para programar. 708-343-8700.**

DRIVEWAYS – PARKING PAD - SIDEWALKS – PATIOS

Submit a completed Building Application along with 2 sets of plans and a plat of survey showing the location of driveway, parking pad, patio or sidewalks to the Building Department.

- When submitting permit locate improvement on your plat of survey include dimensions.
- Concrete driveways must be a minimum of 4" of crushed stone and 5" of concrete.
- Brick pavers must be a minimum of 4" – 6" of crushed stone base, 1" coarse sand, 2 3/8" minimum paver.
- Asphalt must be a minimum of 6" of crushed stone and 2 1/2" – 3" of surface asphalt.
- No driveway shall exceed 24 feet in width except that the width of a driveway may exceed 24 feet at the point that the driveway connects to a garage and from the connection to the garage for a distance not to exceed 30' toward the front lot line.
- No driveway shall have more than one curb cut.
- Circular driveways are prohibited.
- No lot shall have more than one driveway.
- Lots between 5,000 – 6000 sf, no more than 65% may be covered by impervious surfaces.
Lots between 6,001-8,000 sf, no more than 55%
Lots 8,001 sf & over, no more than 50%
- Abutting paved or gravel sidewalks or patios considered as part of driveway for purposes of determining overall width, size and area of driveway.
- A paved parking pad not to exceed 12' x 24' may be constructed adjacent to a garage on a lot provided that it complies with all other requirements of this section.
- No driveway located in a front yard of any lot shall extend more than 12' across the front elevation of the residence located on such lot except when the driveway connects to an attached garage.
- **Pre pour inspection required. Call 24 hours in advance to schedule. 708-343-8700.**

ENTRADAS – ACERAS DE LA PLATAFORMA DE ESTACIONAMIENTO – PATIOS

Envíe una aplicación de construcción completada junto con 2 conjuntos de planes y un plato de estudio que muestra la ubicación de la entrada, el cojín de estacionamiento, el patio o las aceras al Departamento de Construcción.

- Al enviar el permiso localizar la mejora en su plat de encuesta incluyen dimensiones.
- Las entradas de hormigón deben ser un mínimo de 4" de piedra triturada y 5" de hormigón.
- Las pavimentadoras de ladrillo deben ser un mínimo de 4" – 6" de base de piedra triturada, 1" de arena gruesa, 2 3/8" de pavimentación mínima.
- El asfalto debe ser un mínimo de 6" de piedra triturada y 2 1/2" – 3" de asfalto superficial.
- Ninguna entrada excederá los 24 pies de ancho, excepto que la anchura de una entrada puede exceder de 24 pies en el punto en que la entrada se conecta a un garaje y desde la conexión al garaje para una distancia que no exceda de 30' hacia la línea de lote principal.
- Ninguna entrada tendrá más de un corte de bordillo.
- Las entradas circulares están prohibidas.
- Ningún lote tendrá más de una entrada.
- Lotes entre 5.000 y 6000 sf, no más del 65% pueden estar cubiertos por superficies impermeables.
Lotes entre 6.001-8.000 sf, no más del 55%
Lotes 8.001 sf & over, no más del 50%
- Abutting paved o gravel sidewalks or patios considerados como parte de la entrada para determinar la anchura total, el tamaño y el área de entrada.
- Se puede construir una plataforma de aparcamiento pavimentada que no exceda de 12' x 24' adyacente a un garaje en un lote siempre que cumpla con todos los demás requisitos de esta sección.
- Ninguna entrada ubicada en un patio delantero de cualquier lote se extenderá más de 12' a través de la elevación frontal de la residencia ubicada en dicho lote, excepto cuando la entrada se conecta a un garaje adjunto.
- Al enviar el permiso localizar la mejora en su plat de encuesta incluyen dimensiones.
- **Se requiere una inspección previa al vertido. Llame con 24 horas de anticipación para programar. 708-343-8700.**

DRIVEWAYS – PARKING PAD - SIDEWALKS – PATIOS

Submit a completed Building Application along with 2 sets of plans and a plat of survey showing the location of driveway, parking pad, patio or sidewalks to the Building Department.

- When submitting permit locate improvement on your plat of survey include dimensions.
- Concrete driveways must be a minimum of 4" of crushed stone and 5" of concrete.
- Brick pavers must be a minimum of 4" – 6" of crushed stone base, 1" coarse sand, 2 3/8" minimum paver.
- Asphalt must be a minimum of 6" of crushed stone and 2 1/2" – 3" of surface asphalt.
- No driveway shall exceed 24 feet in width except that the width of a driveway may exceed 24 feet at the point that the driveway connects to a garage and from the connection to the garage for a distance not to exceed 30' toward the front lot line.
- No driveway shall have more than one curb cut.
- Circular driveways are prohibited.
- No lot shall have more than one driveway.
- Lots between 5,000 – 6000 sf, no more than 65% may be covered by impervious surfaces.
Lots between 6,001-8,000 sf, no more than 55%
Lots 8,001 sf & over, no more than 50%
- Abutting paved or gravel sidewalks or patios considered as part of driveway for purposes of determining overall width, size and area of driveway.
- A paved parking pad not to exceed 12' x 24' may be constructed adjacent to a garage on a lot provided that it complies with all other requirements of this section.
- No driveway located in a front yard of any lot shall extend more than 12' across the front elevation of the residence located on such lot except when the driveway connects to an attached garage.
- **Pre pour inspection required. Call 24 hours in advance to schedule. 708-343-8700.**

ENTRADAS – ACERAS DE LA PLATAFORMA DE ESTACIONAMIENTO – PATIOS

Envíe una aplicación de construcción completada junto con 2 conjuntos de planes y un plato de estudio que muestra la ubicación de la entrada, el cojín de estacionamiento, el patio o las aceras al Departamento de Construcción.

- Al enviar el permiso localizar la mejora en su plat de encuesta incluyen dimensiones.
- Las entradas de hormigón deben ser un mínimo de 4" de piedra triturada y 5" de hormigón.
- Las pavimentadoras de ladrillo deben ser un mínimo de 4" – 6" de base de piedra triturada, 1" de arena gruesa, 2 3/8" de pavimentación mínima.
- El asfalto debe ser un mínimo de 6" de piedra triturada y 2 1/2" – 3" de asfalto superficial.
- Ninguna entrada excederá los 24 pies de ancho, excepto que la anchura de una entrada puede exceder de 24 pies en el punto en que la entrada se conecta a un garaje y desde la conexión al garaje para una distancia que no exceda de 30' hacia la línea de lote principal.
- Ninguna entrada tendrá más de un corte de bordillo.
- Las entradas circulares están prohibidas.
- Ningún lote tendrá más de una entrada.
- Lotes entre 5.000 y 6000 sf, no más del 65% pueden estar cubiertos por superficies impermeables.
Lotes entre 6.001-8.000 sf, no más del 55%
Lotes 8.001 sf & over, no más del 50%
- Abutting paved o gravel sidewalks or patios considerados como parte de la entrada para determinar la anchura total, el tamaño y el área de entrada.
- Se puede construir una plataforma de aparcamiento pavimentada que no exceda de 12' x 24' adyacente a un garaje en un lote siempre que cumpla con todos los demás requisitos de esta sección.
- Ninguna entrada ubicada en un patio delantero de cualquier lote se extenderá más de 12' a través de la elevación frontal de la residencia ubicada en dicho lote, excepto cuando la entrada se conecta a un garaje adjunto.
- Al enviar el permiso localizar la mejora en su plat de encuesta incluyen dimensiones.
- **Se requiere una inspección previa al vertido. Llame con 24 horas de anticipación para programar. 708-343-8700.**

DRIVEWAYS – PARKING PAD - SIDEWALKS – PATIOS

Submit a completed Building Application along with 2 sets of plans and a plat of survey showing the location of driveway, parking pad, patio or sidewalks to the Building Department.

- When submitting permit locate improvement on your plat of survey include dimensions.
- Concrete driveways must be a minimum of 4" of crushed stone and 5" of concrete.
- Brick pavers must be a minimum of 4" – 6" of crushed stone base, 1" coarse sand, 2 3/8" minimum paver.
- Asphalt must be a minimum of 6" of crushed stone and 2 1/2" – 3" of surface asphalt.
- No driveway shall exceed 24 feet in width except that the width of a driveway may exceed 24 feet at the point that the driveway connects to a garage and from the connection to the garage for a distance not to exceed 30' toward the front lot line.
- No driveway shall have more than one curb cut.
- Circular driveways are prohibited.
- No lot shall have more than one driveway.
- Lots between 5,000 – 6000 sf, no more than 65% may be covered by impervious surfaces.
Lots between 6,001-8,000 sf, no more than 55%
Lots 8,001 sf & over, no more than 50%
- Abutting paved or gravel sidewalks or patios considered as part of driveway for purposes of determining overall width, size and area of driveway.
- A paved parking pad not to exceed 12' x 24' may be constructed adjacent to a garage on a lot provided that it complies with all other requirements of this section.
- No driveway located in a front yard of any lot shall extend more than 12' across the front elevation of the residence located on such lot except when the driveway connects to an attached garage.
- **Pre pour inspection required. Call 24 hours in advance to schedule. 708-343-8700.**

ENTRADAS – ACERAS DE LA PLATAFORMA DE ESTACIONAMIENTO – PATIOS

Envíe una aplicación de construcción completada junto con 2 conjuntos de planes y un plato de estudio que muestra la ubicación de la entrada, el cojín de estacionamiento, el patio o las aceras al Departamento de Construcción.

- Al enviar el permiso localizar la mejora en su plat de encuesta incluyen dimensiones.
- Las entradas de hormigón deben ser un mínimo de 4" de piedra triturada y 5" de hormigón.
- Las pavimentadoras de ladrillo deben ser un mínimo de 4" – 6" de base de piedra triturada, 1" de arena gruesa, 2 3/8" de pavimentación mínima.
- El asfalto debe ser un mínimo de 6" de piedra triturada y 2 1/2" – 3" de asfalto superficial.
- Ninguna entrada excederá los 24 pies de ancho, excepto que la anchura de una entrada puede exceder de 24 pies en el punto en que la entrada se conecta a un garaje y desde la conexión al garaje para una distancia que no exceda de 30' hacia la línea de lote principal.
- Ninguna entrada tendrá más de un corte de bordillo.
- Las entradas circulares están prohibidas.
- Ningún lote tendrá más de una entrada.
- Lotes entre 5.000 y 6000 sf, no más del 65% pueden estar cubiertos por superficies impermeables.
Lotes entre 6.001-8.000 sf, no más del 55%
Lotes 8.001 sf & over, no más del 50%
- Abutting paved o gravel sidewalks or patios considerados como parte de la entrada para determinar la anchura total, el tamaño y el área de entrada.
- Se puede construir una plataforma de aparcamiento pavimentada que no exceda de 12' x 24' adyacente a un garaje en un lote siempre que cumpla con todos los demás requisitos de esta sección.
- Ninguna entrada ubicada en un patio delantero de cualquier lote se extenderá más de 12' a través de la elevación frontal de la residencia ubicada en dicho lote, excepto cuando la entrada se conecta a un garaje adjunto.
- Al enviar el permiso localizar la mejora en su plat de encuesta incluyen dimensiones.
- **Se requiere una inspección previa al vertido. Llame con 24 horas de anticipación para programar. 708-343-8700.**

DRIVEWAYS – PARKING PAD - SIDEWALKS – PATIOS

Submit a completed Building Application along with 2 sets of plans and a plat of survey showing the location of driveway, parking pad, patio or sidewalks to the Building Department.

- When submitting permit locate improvement on your plat of survey include dimensions.
- Concrete driveways must be a minimum of 4" of crushed stone and 5" of concrete.
- Brick pavers must be a minimum of 4" – 6" of crushed stone base, 1" coarse sand, 2 3/8" minimum paver.
- Asphalt must be a minimum of 6" of crushed stone and 2 1/2" – 3" of surface asphalt.
- No driveway shall exceed 24 feet in width except that the width of a driveway may exceed 24 feet at the point that the driveway connects to a garage and from the connection to the garage for a distance not to exceed 30' toward the front lot line.
- No driveway shall have more than one curb cut.
- Circular driveways are prohibited.
- No lot shall have more than one driveway.
- Lots between 5,000 – 6000 sf, no more than 65% may be covered by impervious surfaces.
Lots between 6,001-8,000 sf, no more than 55%
Lots 8,001 sf & over, no more than 50%
- Abutting paved or gravel sidewalks or patios considered as part of driveway for purposes of determining overall width, size and area of driveway.
- A paved parking pad not to exceed 12' x 24' may be constructed adjacent to a garage on a lot provided that it complies with all other requirements of this section.
- No driveway located in a front yard of any lot shall extend more than 12' across the front elevation of the residence located on such lot except when the driveway connects to an attached garage.
- **Pre pour inspection required. Call 24 hours in advance to schedule. 708-343-8700.**

ENTRADAS – ACERAS DE LA PLATAFORMA DE ESTACIONAMIENTO – PATIOS

Envíe una aplicación de construcción completada junto con 2 conjuntos de planes y un plato de estudio que muestra la ubicación de la entrada, el cojín de estacionamiento, el patio o las aceras al Departamento de Construcción.

- Al enviar el permiso localizar la mejora en su plat de encuesta incluyen dimensiones.
- Las entradas de hormigón deben ser un mínimo de 4" de piedra triturada y 5" de hormigón.
- Las pavimentadoras de ladrillo deben ser un mínimo de 4" – 6" de base de piedra triturada, 1" de arena gruesa, 2 3/8" de pavimentación mínima.
- El asfalto debe ser un mínimo de 6" de piedra triturada y 2 1/2" – 3" de asfalto superficial.
- Ninguna entrada excederá los 24 pies de ancho, excepto que la anchura de una entrada puede exceder de 24 pies en el punto en que la entrada se conecta a un garaje y desde la conexión al garaje para una distancia que no exceda de 30' hacia la línea de lote principal.
- Ninguna entrada tendrá más de un corte de bordillo.
- Las entradas circulares están prohibidas.
- Ningún lote tendrá más de una entrada.
- Lotes entre 5.000 y 6000 sf, no más del 65% pueden estar cubiertos por superficies impermeables.
Lotes entre 6.001-8.000 sf, no más del 55%
Lotes 8.001 sf & over, no más del 50%
- Abutting paved o gravel sidewalks or patios considerados como parte de la entrada para determinar la anchura total, el tamaño y el área de entrada.
- Se puede construir una plataforma de aparcamiento pavimentada que no exceda de 12' x 24' adyacente a un garaje en un lote siempre que cumpla con todos los demás requisitos de esta sección.
- Ninguna entrada ubicada en un patio delantero de cualquier lote se extenderá más de 12' a través de la elevación frontal de la residencia ubicada en dicho lote, excepto cuando la entrada se conecta a un garaje adjunto.
- Al enviar el permiso localizar la mejora en su plat de encuesta incluyen dimensiones.
- **Se requiere una inspección previa al vertido. Llame con 24 horas de anticipación para programar. 708-343-8700.**

DRIVEWAYS – PARKING PAD - SIDEWALKS – PATIOS

Submit a completed Building Application along with 2 sets of plans and a plat of survey showing the location of driveway, parking pad, patio or sidewalks to the Building Department.

- When submitting permit locate improvement on your plat of survey include dimensions.
- Concrete driveways must be a minimum of 4" of crushed stone and 5" of concrete.
- Brick pavers must be a minimum of 4" – 6" of crushed stone base, 1" coarse sand, 2 3/8" minimum paver.
- Asphalt must be a minimum of 6" of crushed stone and 2 1/2" – 3" of surface asphalt.
- No driveway shall exceed 24 feet in width except that the width of a driveway may exceed 24 feet at the point that the driveway connects to a garage and from the connection to the garage for a distance not to exceed 30' toward the front lot line.
- No driveway shall have more than one curb cut.
- Circular driveways are prohibited.
- No lot shall have more than one driveway.
- Lots between 5,000 – 6000 sf, no more than 65% may be covered by impervious surfaces.
Lots between 6,001-8,000 sf, no more than 55%
Lots 8,001 sf & over, no more than 50%
- Abutting paved or gravel sidewalks or patios considered as part of driveway for purposes of determining overall width, size and area of driveway.
- A paved parking pad not to exceed 12' x 24' may be constructed adjacent to a garage on a lot provided that it complies with all other requirements of this section.
- No driveway located in a front yard of any lot shall extend more than 12' across the front elevation of the residence located on such lot except when the driveway connects to an attached garage.
- **Pre pour inspection required. Call 24 hours in advance to schedule. 708-343-8700.**

ENTRADAS – ACERAS DE LA PLATAFORMA DE ESTACIONAMIENTO – PATIOS

Envíe una aplicación de construcción completada junto con 2 conjuntos de planes y un plato de estudio que muestra la ubicación de la entrada, el cojín de estacionamiento, el patio o las aceras al Departamento de Construcción.

- Al enviar el permiso localizar la mejora en su plat de encuesta incluyen dimensiones.
- Las entradas de hormigón deben ser un mínimo de 4" de piedra triturada y 5" de hormigón.
- Las pavimentadoras de ladrillo deben ser un mínimo de 4" – 6" de base de piedra triturada, 1" de arena gruesa, 2 3/8" de pavimentación mínima.
- El asfalto debe ser un mínimo de 6" de piedra triturada y 2 1/2" – 3" de asfalto superficial.
- Ninguna entrada excederá los 24 pies de ancho, excepto que la anchura de una entrada puede exceder de 24 pies en el punto en que la entrada se conecta a un garaje y desde la conexión al garaje para una distancia que no exceda de 30' hacia la línea de lote principal.
- Ninguna entrada tendrá más de un corte de bordillo.
- Las entradas circulares están prohibidas.
- Ningún lote tendrá más de una entrada.
- Lotes entre 5.000 y 6000 sf, no más del 65% pueden estar cubiertos por superficies impermeables.
Lotes entre 6.001-8.000 sf, no más del 55%
Lotes 8.001 sf & over, no más del 50%
- Abutting paved o gravel sidewalks or patios considerados como parte de la entrada para determinar la anchura total, el tamaño y el área de entrada.
- Se puede construir una plataforma de aparcamiento pavimentada que no exceda de 12' x 24' adyacente a un garaje en un lote siempre que cumpla con todos los demás requisitos de esta sección.
- Ninguna entrada ubicada en un patio delantero de cualquier lote se extenderá más de 12' a través de la elevación frontal de la residencia ubicada en dicho lote, excepto cuando la entrada se conecta a un garaje adjunto.
- Al enviar el permiso localizar la mejora en su plat de encuesta incluyen dimensiones.
- **Se requiere una inspección previa al vertido. Llame con 24 horas de anticipación para programar. 708-343-8700.**

DRIVEWAYS – PARKING PAD - SIDEWALKS – PATIOS

Submit a completed Building Application along with 2 sets of plans and a plat of survey showing the location of driveway, parking pad, patio or sidewalks to the Building Department.

- When submitting permit locate improvement on your plat of survey include dimensions.
- Concrete driveways must be a minimum of 4" of crushed stone and 5" of concrete.
- Brick pavers must be a minimum of 4" – 6" of crushed stone base, 1" coarse sand, 2 3/8" minimum paver.
- Asphalt must be a minimum of 6" of crushed stone and 2 1/2" – 3" of surface asphalt.
- No driveway shall exceed 24 feet in width except that the width of a driveway may exceed 24 feet at the point that the driveway connects to a garage and from the connection to the garage for a distance not to exceed 30' toward the front lot line.
- No driveway shall have more than one curb cut.
- Circular driveways are prohibited.
- No lot shall have more than one driveway.
- Lots between 5,000 – 6000 sf, no more than 65% may be covered by impervious surfaces.
Lots between 6,001-8,000 sf, no more than 55%
Lots 8,001 sf & over, no more than 50%
- Abutting paved or gravel sidewalks or patios considered as part of driveway for purposes of determining overall width, size and area of driveway.
- A paved parking pad not to exceed 12' x 24' may be constructed adjacent to a garage on a lot provided that it complies with all other requirements of this section.
- No driveway located in a front yard of any lot shall extend more than 12' across the front elevation of the residence located on such lot except when the driveway connects to an attached garage.
- **Pre pour inspection required. Call 24 hours in advance to schedule. 708-343-8700.**

ENTRADAS – ACERAS DE LA PLATAFORMA DE ESTACIONAMIENTO – PATIOS

Envíe una aplicación de construcción completada junto con 2 conjuntos de planes y un plato de estudio que muestra la ubicación de la entrada, el cojín de estacionamiento, el patio o las aceras al Departamento de Construcción.

- Al enviar el permiso localizar la mejora en su plat de encuesta incluyen dimensiones.
- Las entradas de hormigón deben ser un mínimo de 4" de piedra triturada y 5" de hormigón.
- Las pavimentadoras de ladrillo deben ser un mínimo de 4" – 6" de base de piedra triturada, 1" de arena gruesa, 2 3/8" de pavimentación mínima.
- El asfalto debe ser un mínimo de 6" de piedra triturada y 2 1/2" – 3" de asfalto superficial.
- Ninguna entrada excederá los 24 pies de ancho, excepto que la anchura de una entrada puede exceder de 24 pies en el punto en que la entrada se conecta a un garaje y desde la conexión al garaje para una distancia que no exceda de 30' hacia la línea de lote principal.
- Ninguna entrada tendrá más de un corte de bordillo.
- Las entradas circulares están prohibidas.
- Ningún lote tendrá más de una entrada.
- Lotes entre 5.000 y 6000 sf, no más del 65% pueden estar cubiertos por superficies impermeables.
Lotes entre 6.001-8.000 sf, no más del 55%
Lotes 8.001 sf & over, no más del 50%
- Abutting paved o gravel sidewalks or patios considerados como parte de la entrada para determinar la anchura total, el tamaño y el área de entrada.
- Se puede construir una plataforma de aparcamiento pavimentada que no exceda de 12' x 24' adyacente a un garaje en un lote siempre que cumpla con todos los demás requisitos de esta sección.
- Ninguna entrada ubicada en un patio delantero de cualquier lote se extenderá más de 12' a través de la elevación frontal de la residencia ubicada en dicho lote, excepto cuando la entrada se conecta a un garaje adjunto.
- Al enviar el permiso localizar la mejora en su plat de encuesta incluyen dimensiones.
- **Se requiere una inspección previa al vertido. Llame con 24 horas de anticipación para programar. 708-343-8700.**